


Photo 2 - Angle 2



Signatures & Approval

S.A.E (UIDSSMT)
DUBRAJPUR MUNICIPALITY
Dubrajpur, Birbhum

Seal with signature of ULB Engineer

Name: Salit Sefhu

Contact no.: 9832530829

Signature of Engineer

HILLI INSPIRATION

Name: _____

Contact no.: 601101586

HILLI INSPIRATION
Engineer (Civil)

Checked & Verified

Checked & Verified

20.11.25
Engineer (Civil)
HILLI INSPIRATION

Signature of Co-Ordinator

HILLI INSPIRATION

Co-ordinator
HILLI INSPIRATION

[Download PDF](#)



DUBRAJPUR MUNICIPALITY
CONSTRUCTION SITE FIRST VISIT REPORT

First Visit : PROP-00029 - NEAR UTTARANCHAL CLUB

Location Details

Name of the Location	Latitude & Longitude	Ward	Area	Area Unit
NEAR UTTARANCHAL CLUB	22.5798083 88.4134454	2	0.34	Acre

Project Details

Proposed Project Type	Toilet Seat (Male)	Toilet Seat (Female)	Urinal Seat (Male)	Urinal Seat (Female)
PT (Public Toilet Project)	2	2	2	2

Land Details

Classification	Plot No.	Jl No.	Dag No.	Khatian No.	Mouza	Possession Details (Owned by)
Bastu	402	138	0	0	JANGAL DUBRAJPUR	

Construction Site First Visit Report

Foundation upto Tie beam with reinforcement details						
Visit Date	18/11/2025					
Earth Cutting (1200 x 1200 x 1000)	Column Nos.	Length (M)	Breath (M)	Height (M)	Status	Remarks
	10	1200	1200	1000	OK	OK

Earth Cutting Image



Re-inforcement

Footing
(10 mm dia 10 nos both)

Rod Nos.	Diameter (M)	Status	Remarks
10	10	OK	OK

Footing Image




Column
(12 mm dia 6 nos)

Rod Nos.	Diameter (M)	Length (M)	Height (M)	Status	Remarks
6	12	250	250	OK	OK

Column Image



Tie beam (12 mm dia 4 nos)	<table border="1"> <thead> <tr> <th>Rod Nos.</th> <th>Diameter (M)</th> <th>Length (M)</th> <th>Breath (M)</th> <th>Status</th> <th>Remarks</th> </tr> </thead> <tbody> <tr> <td>4</td> <td>12</td> <td>250</td> <td>250</td> <td>OK</td> <td>OK</td> </tr> </tbody> </table>	Rod Nos.	Diameter (M)	Length (M)	Breath (M)	Status	Remarks	4	12	250	250	OK	OK
Rod Nos.	Diameter (M)	Length (M)	Breath (M)	Status	Remarks								
4	12	250	250	OK	OK								
Tie beam Image													
Binder for Column 8 mm dia 175 mm C/C	<table border="1"> <thead> <tr> <th>Status</th> <th>Remarks</th> </tr> </thead> <tbody> <tr> <td>OK</td> <td>OK</td> </tr> </tbody> </table>	Status	Remarks	OK	OK								
Status	Remarks												
OK	OK												
Binder for Tie 8 mm dia 175 mm C/C	<table border="1"> <thead> <tr> <th>Status</th> <th>Remarks</th> </tr> </thead> <tbody> <tr> <td>OK</td> <td>OK</td> </tr> </tbody> </table>	Status	Remarks	OK	OK								
Status	Remarks												
OK	OK												
Overall Reamrks	Ok												

Overall Work Status - Images	
Photo 1 - Angle 1	