



HALDIBARI MUNICIPALITY
CONSTRUCTION SITE FIRST VISIT REPORT

First Visit - PWDP 2023 - Hospital Para Haldibari High School (Female)

Location Details

Name of the Location	Latitude & Longitude	Ward	Area	Area Unit
Hospital Para Haldibari High School (Female)	26.571801 88.4921812	1	Hospital Para	22.7 Sq/Meter





Project Details

Proposed Project Type	Toilet Seat (Male)	Toilet Seat (Female)	Urinal Seat (Male)	Urinal Seat (Female)
toilet	1	2	2	1

Land Details

Classification	Plot No.	J. No.	Seg. No.	Station No.	Waste	Possession Details (Owned By)
toilet	30427	021	30427	104-12	WADA HALL, Haldibari	

Foundation up to Tie beam with reinforcement details

Part	Ref No.	Length (M)	Breadth (M)	Height (M)	Status	Remarks
Footling (12 mm dia 10 nos)	35	1.00	1.00	0.00	OK	OK
Footling Image						
Footling (10 mm dia 10 nos width)	36				OK	OK
Footling Image						
Column (12 mm dia 6 nos)	6	1.2	2.50	2.50	OK	OK
Column Image						
Tie beam (12 mm dia 4 nos)	4	1.2	2.50	2.50	OK	OK
Tie beam Image						
Slinder for Column 8 mm dia 175 mm C/C					Status	Remarks
					OK	OK
Slinder for Tie 8 mm dia 175 mm C/C					Status	Remarks
					OK	OK
Overall Remarks					OK	



Signatures & Approval

Atcharya

Sub-Assistant Engineer,
Haldibari Municipality
Haldibari, Cooch Behar

Send with signature of ULR Engineer
Name: _____
Contact no.: _____

Checked & Verified

Arup Kumar
29-11-25

Engineer (Civil)
Hijli INSPIRATION

Signature of Engineer
HILJI INSPIRATION
Name: _____
Contact no.: _____

Schattachari

Co-ordinator
Hijli INSPIRATION

Signature of Co-Ordinator
HILJI INSPIRATION