



DINHATA MUNICIPALITY
CONSTRUCTION SITE FIRST VISIT REPORT

First Visit : PROP-00302 - NETAJI BAZAR COLLEGE PARA

Location Details

Name of the Location	Latitude & Longitude	Ward	Area	Area Unit
NETAJI BAZAR COLLEGE PARA	26.3371128 89.4501445	1	COLLEGE PARA , WARD NO-01, DINHATA	22.5 Sq/Meter

Project Details

Proposed Project Type	Toilet Seat (Male)	Toilet Seat (Female)	Urinal Seat (Male)	Urinal Seat (Female)
Bastu	1	1	2	1

Land Details

Classification	Plot No.	Jl No.	Dag No.	Khatian No.	Mouza	Possession Details (Owned by)
Bastu	8100	108	NO	NO	DINHATA	

Construction Site First Visit Report

Foundation upto Tie beam with reinforcement details

Visit Date	06/12/2025					
Earth Cutting (1200 x 1200 x 1000)	Column Nos.	Length (M)	Breath (M)	Height (M)	Status	Remarks
	10	1200	1200	1000	OK	OK

Earth Cutting Image



Lat: 26.14505
 Long: 89.46319
 Location: Dinhata, West Bengal

Re-inforcement

Footing
 (10 mm dia 10 nos both)

Rod Nos.	Diameter (M)	Status	Remarks
10	10	OK	OK

Footing Image



Lat: 26.14507
 Long: 89.46324
 Location: Dinhata, West Bengal

Column
 (12 mm dia 6 nos)

Rod Nos.	Diameter (M)	Length (M)	Height (M)	Status	Remarks
6	12	250	250	OK	OK

Column Image



Lat: 26.14539
 Long: 89.46314
 Location: Dinhata, West Bengal

Beam
2 mm dia 4 nos)

Rod Nos.	Diameter (M)	Length (M)	Breath (M)	Status	Remarks
4	12	250	250	OK	OK

Tie beam Image



Binder for Column 8 mm dia 175 mm C/C

Status	Remarks
OK	OK

Binder for Tie 8 mm dia 175 mm C/C

Status	Remarks
OK	OK

Overall Reamrks

Excavation work is currently in progress due to the land condition. However, all reinforcement has been provided as per the approved drawing.

Overall Work Status - Images

Photo 1 - Angle 1





Signatures & Approval

[Signature]
Sub Assistant Engineer
Dhaka Municipality

Sent with signature of Sub Engineer
Name: *M. Nazim A. Hossain*
Contact no: *5533631725*

Checked & Verified
[Signature]
Engineer (Civil)
HSE INSPIRATION

Signature of Engineer
Name: _____
Contact no: _____

[Signature]
Co-ordinator
HSE INSPIRATION

Signature of Co-ordinator
Name: _____

Approved