



HALISAHAR MUNICIPALITY

CONSTRUCTION SITE FIRST VISIT REPORT

First Visit : PROP-00303 - HALISAHAR PRIMARY SCHOOL, Ghosh para, Road, beside HALISAHAR, Halisahar, Municipality, 743134

Location Details

| Name of the Location | Latitude & Longitude | Ward | Area | Area Unit |
|---|--------------------------|------|------|-----------|
| HALISAHAR PRIMARY SCHOOL, Ghosh para, Road, beside HALISAHAR, Halisahar, Municipality, 743134 | 22.5797372 88.4135499 | 6 | 45 | Sq/Meter |

Project Details

| Proposed Project Type | Toilet Seat (Male) | Toilet Seat (Female) | Urinal Seat (Male) | Urinal Seat (Female) |
|-----------------------|--------------------|----------------------|--------------------|----------------------|
| Bastu | 1 | 1 | 2 | 1 |

Land Details

| Classification | Plot No. | Jl No. | Dag No. | Khatian No. | Mouza | Possession Details (Owned by) |
|----------------|----------|--------|---------|-------------|-----------|-------------------------------|
| Bastu | 1646 | 06 | 1646 | 8311 | HALISAHAR | |

Foundation upto Tie beam with reinforcement details

Visit Date

29/12/2025

Earth Cutting
(1200 x 1200 x 1000)

| Column Nos. | Length (M) | Breath (M) | Height (M) | Status | Remarks |
|-------------|------------|------------|------------|--------|---------|
| 10 | 1200 | 1200 | 1000 | OK | OK |

Earth Cutting Image



Re-inforcement

Footing
(10 mm dia 10 nos both)

| Rod Nos. | Diameter (M) | Status | Remarks |
|----------|--------------|--------|---------|
| 10 | 10 | OK | OK |

Footing Image



Column
(12 mm dia 6 nos)

| Rod Nos. | Diameter (M) | Length (M) | Height (M) | Status | Remarks |
|----------|--------------|------------|------------|--------|---------|
| 6 | 12 | 250 | 250 | OK | OK |

Column Image



Tie beam
(12 mm dia 4 nos)

| Rod Nos. | Diameter (M) | Length (M) | Breath (M) | Status | Remarks |
|----------|--------------|------------|------------|--------|---------|
| 4 | 12 | 250 | 250 | OK | OK |

Tie beam Image



Binder for Column 8 mm dia 175 mm C/C

| Status | Remarks |
|--------|---------|
| OK | OK |

Binder for Tie 8 mm dia 175 mm C/C

| Status | Remarks |
|--------|---------|
| | |

Overall Work Status - Images

Photo 1 - Angle 1



Photo 2 - Angle 2



QR Code Board Image



Signatures & Approval

Seal with signature of ULB Engineer
Name: Diptendu Sarkar
Contact no.: 8420850290

**SUB. ASSISTANT ENGINEER
HALISAHAR MUNICIPALITY**

Checked & Verified

**Engineer (Civil)
HILLI INSPIRATION**

Signature of Engineer
HILLI INSPIRATION

Name: _____
Contact no.: _____

**Co-ordinator
HILLI INSPIRATION**

Signature of Co-Ordinator
HILLI INSPIRATION