



GUSKARA MUNICIPALITY

CONSTRUCTION SITE FIRST VISIT REPORT

First Visit : PROP-01102 - GUSKARA MAHAVIDYALAYA

Location Details

| Name of the location  | Latitude & Longitude     | Ward | Area    | Area Unit |
|-----------------------|--------------------------|------|---------|-----------|
| GUSKARA MAHAVIDYALAYA | 22.5797662<br>88.4135047 | 4    | GUSKARA | Sq/Meter  |

Project Details

| Proposed Project Type      | Toilet Seat (Male) | Toilet Seat (Female) | Urinal Seat (Male) | Urinal Seat (Female) |
|----------------------------|--------------------|----------------------|--------------------|----------------------|
| Institutional Toilet Block | 3                  | 3                    | 3                  | 3                    |

Land Details

| Classification | Plot No. | Jl No. | Dag No. | Khatian No. | Mouza   | Possession Details (Owned by) |
|----------------|----------|--------|---------|-------------|---------|-------------------------------|
| Other          | 2273     | 110    | 2273    | 636         | GUSKARA |                               |

1

Checked & Verified  
*Pradeep Kumar*  
Page 1 of 3

Engineer (Civil)  
Hill INSPIRATION




Foundation upto Tie beam with reinforcement details

27/01/2026

| Visit Date | Column Nos. | Length (M) | Breath (M) | Height (M) | Status | Remarks |
|------------|-------------|------------|------------|------------|--------|---------|
| 27/01/2026 | 10          | 1200       | 1200       | 1000       | OK     | OK      |

Earth Cutting  
(1200 x 1200 x 1000)




Earth Cutting Image

Re-Inforcement

| Footling                | Reinforcement | Remarks |
|-------------------------|---------------|---------|
| (10 mm dia 10 nos both) | 10            | OK      |


Footling Image



Column  
(12 mm dia 6 nos)

| Column            | Reinforcement | Remarks |
|-------------------|---------------|---------|
| (12 mm dia 6 nos) | 6             | OK      |

Column Image



Tie beam  
(12 mm dia 4 nos)

| Tie beam          | Reinforcement | Remarks |
|-------------------|---------------|---------|
| (12 mm dia 4 nos) | 4             | OK      |

Tie beam Image



Checked & Verified  
*Pradeep Mukherjee*  
 Engineer (Civil)  
 Hiji INSPIRATION

Photo 1 - Angle 1





Photo 2 - Angle 2



QR Code Board Image



Signatures & Approval

*[Handwritten Signature]*  
28/01/2028.

Seal with signature of UI B Engineer  
Name: Saptaraj Kumar Mishra  
Contact no: 9851104445

S. A. E.  
Guskara Municipality

*[Handwritten Signature]* 28/01/28  
Checked & Verified

Signature of Engineer  
HILL INSPIRATION  
Name: Pradip Kumar Saha Engineer (Civil)  
Contact no: 9335825523 Hill INSPIRATION

*[Handwritten Signature]*  
Co-ordinator  
HILL INSPIRATION