



KALYANI MUNICIPALITY
CONSTRUCTION SITE FIRST VISIT REPORT

First Visit : PROP-01305 - Rathtala Kanchan Pally Bazer

Location Details

| Name of the Location | Latitude & Longitude | Ward | Area | Area Unit |
|------------------------------|--------------------------|------|------|-----------|
| Rathtala Kanchan Pally Bazer | 22.5796948 88.4135211 | 18 | 29 | Sq/Meter |

Project Details

| Proposed Project Type | Toilet Seat (Male) | Toilet Seat (Female) | Urinal Seat (Male) | Urinal Seat (Female) |
|----------------------------|--------------------|----------------------|--------------------|----------------------|
| PT (Public Toilet Project) | 2 | 2 | 3 | 2 |

Land Details


| Classification | Plot No. | JI No. | Dag No. | Khatian No. | Mouza | Possession Details (Owned by) |
|----------------|----------|--------|---------|-------------|---------|-------------------------------|
| Other | NA | 58 | NA | NA | KALYANI | |

Construction Site First Visit Report

| Foundation upto Tie beam with reinforcement details | | | | | | |
|---|-------------|------------|------------|------------|--------|---------|
| Visit Date | 29/12/2025 | | | | | |
| Earth Cutting (1200 x 1200 x 1000) | Column Nos. | Length (M) | Breath (M) | Height (M) | Status | Remarks |
| | 10 | 1200 | 1200 | 1000 | OK | OK |



Earth Cutting Image



Re-inforcement

Footing
(10 mm dia 10 nos both)

| Rod Nos. | Diameter (M) | Status | Remarks |
|----------|--------------|--------|---------|
| 10 | 10 | OK | OK |


Footing Image



Column
(12 mm dia 6 nos)

| Rod Nos. | Diameter (M) | Length (M) | Height (M) | Status | Remarks |
|----------|--------------|------------|------------|--------|---------|
| 6 | 12 | 250 | 250 | OK | OK |


Column Image



**Tie beam
(12 mm dia 4 nos)**

| Rod Nos. | Diameter (M) | Length (M) | Breath (M) | Status | Remarks |
|----------|--------------|------------|------------|--------|---------|
| 4 | 12 | 250 | 250 | OK | OK |

Tie beam Image



Binder for Column 8 mm dia 175 mm C/C

| Status | Remarks |
|--------|---------|
| OK | OK |

Binder for Tie 8 mm dia 175 mm C/C

| Status | Remarks |
|--------|---------|
| OK | OK |

Overall Remarks

Ok

Photo 1 - Angle 1





Photo 2 - Angle 2



QR Code Board Image



Seal with signature of ULB Engineer
Name: [Signature]
Contact no: Municipal Civil Engineer
CLTC
Kalyani Municipality,

[Signature]
Signature of Engineer
HILLI INSPIRATION
Name: SUPRMO A WDSH
Contact no: 8629025878
Checked & Verified

Engineer (Civil)
Hijli INSPIRATION



[Signature] 9679 828902

Signature of Co-Ordinator **Co-ordinator**
HILLI INSPIRATION **Hijli INSPIRATION**

[Download PDF](#)