



RAIGANJ MUNICIPALITY
CONSTRUCTION SITE SECOND VISIT REPORT

Second Visit : PROP-00036 - Shaktinagar Graveyard

Location Details

Name of the Location	Latitude & Longitude	Ward	Area	Area Unit
Shaktinagar Graveyard	22.579729 88.4135567	8	Shaktinagar Graveyard	Acre


Project Details

Proposed Project Type	Toilet Seat (Male)	Toilet Seat (Female)	Urinal Seat (Male)	Urinal Seat (Female)
PT (Public Toilet Project)	4	4	4	4


Land Details

Classification	Plot No.	Jl No.	Dag No.	Khatian No.	Mouza	Possession Details (Owned by)
Other	4447	151	4447	1090,3692	Mohanbati	

Construction Site Second Visit Report

At the time of Roof Casting - Visit Details				
Visit Date	24/02/2026			
Roof Beam Top Support (16 mm dia, 4 nos.)	Rod Nos.	Diameter (mm)	Status	Remarks
	4	16	OK	OK
Roof Beam Top Support Image				
Roof Beam Bottom Support (16 mm dia, 2 nos.)	Rod Nos.	Diameter (mm)	Status	Remarks
	2	16	OK	OK

Roof Beam Bottom Support Image



Roof Beam Mid Span Top Support
(16 mm dia 2 nos)

Rod Nos.	Diameter (mm)	Status	Remarks
2	16	OK	OK


Roof Beam Mid Span Top Support Image



Roof Beam Mid Span Bottom Support
(16 mm dia 4 nos)

Rod Nos.	Diameter (mm)	Status	Remarks
4	16	OK	OK


Roof Beam Mid Span Bottom Support Image



Roof Details Parameters
(8 mm dia 125 nos)

Diameter (mm)	Depth (mm)	Status	Remarks
8	125	OK	OK

Roof Details Parameters Image



Binder for Roof Beam Support (250mm X 250mm)

Status	Remarks
OK	OK

Binder for Roof Beam Mid Span Support

Status	Remarks
OK	OK

Binder for Roof 8mm dia 125mm C/C

Status	Remarks
OK	OK

Overall Remarks


Ok

Overall Work Status - Images


Photo 1 - Angle 1



Photo 2 - Angle 2



Signatures & Approval


Sub-Assistant Engineer
Raiganj Municipality

Utt: Seal with signature of ULB Engineer
Name: Subrata Sarkar
Contact no.: 94349-85989


Co-ordinator
HILLI INSPIRATION

Signature of Co-Ordinator
HILLI INSPIRATION

Signature of Engineer
HILLI INSPIRATION

Name: _____
Contact no.: _____

[Download PDF](#)