



DUBRAJPUR MUNICIPALITY
CONSTRUCTION SITE SECOND VISIT REPORT

Second Visit : PROP.00060 - DANGALPARA IMAMBARA

Location Details

Name of the Location	Latitude & Longitude	Ward	Area	Area Unit
DANGALPARA IMAMBARA	22.5797348 88.4135295	8	0.018	Acre

Project Details

Proposed Project Type	Toilet Seat (Male)	Toilet Seat (Female)	Urinal Seat (Male)	Urinal Seat (Female)
CT (Community Toilet Project)	2	2	2	2

Land Details

Classification	Plot No.	Jl No.	Dag No.	Khatian No.	Mouza	Possession Details (Owned by)
Bastu	1508	140	0	232/5	ISLAMPUR	

Construction Site Second Visit Report

At the time of Roof Casting - Visit Details

Visit Date	07/04/2026			
Roof Beam Top Support (16 mm dia, 4 nos.)	Rod Nos.	Diameter (mm)	Status	Remarks
	4	16	OK	OK

Roof Beam Top Support Image



Roof Beam Bottom Support
(16 mm dia, 2 nos.)

Rod Nos.	Diameter (mm)	Status	Remarks
2	16	OK	OK

Roof Beam Bottom Support Image



Roof Beam Mid Span Top Support
(16 mm dia 2 nos)

Rod Nos.	Diameter (mm)	Status	Remarks
2	16	OK	OK


Roof Beam Mid Span Top Support Image



Roof Beam Mid Span Bottom Support
(16 mm dia 4 nos)

Rod Nos.	Diameter (mm)	Status	Remarks
4	16	OK	OK

Roof Beam Mid Span Bottom Support Image



Roof Details Parameters
(8 mm dia 125 nos)

Diameter (mm)	Depth (mm)	Status	Remarks
8	125	OK	OK

Roof Details Parameters Image



Binder for Roof Beam Support
(250mm X 250mm)

Status
OK

Remarks
OK

Binder for Roof Beam Mid Span Support

Status
OK

Remarks
OK

Binder for Roof 8mm dia 125mm C/C

Status
OK

Remarks
OK

Overall Remarks


As per the drawing, there are 7 columns required here. However, since an old building is adjacent, construction of all columns is not possible. Therefore, 3 columns have been newly provided, and the remaining 4 columns have been taken from the existing building and no new mid beam has been provided. Therefore, half of the roof is newly constructed, and the other half belongs to the existing building.

Overall Work Status - Images

Photo 1 - Angle 1



Photo 2 - Angle 2



Signatures & Approval

Sayed
 SAE
 Dubrajpur Municipality
 District Engineer Bimphum
 District Engineer of ULB Engineer
 Name: Sayed Saifuddin
 Contact no.: 9749937575

Checked & Verified
Ghosh
 Engineer (Civil)
 Hilli INSPIRATION
 Signature of Engineer
 HILLI INSPIRATION
 Name: SUPROMO GHOSH
 Contact no.: 8622075848

M. Saha
 Co-ordinator
 Hilli INSPIRATION
 Signature of Co-Ordinator
 HILLI INSPIRATION