



DUBRAJPUR MUNICIPALITY

CONSTRUCTION SITE SECOND VISIT REPORT

Second Visit : PROP-00061 - DANGALPARA NERA MADRASHA ASHRAFIA RIZWIA

Location Details

Name of the Location	Latitude & Longitude	Ward	Area	Area Unit
DANGALPARA NERA MADRASHA ASHRAFIA RIZWIA	22.5797096 88.4135345	8	0.031	Acre

Project Details

Proposed Project Type	Toilet Seat (Male)	Toilet Seat (Female)	Urinal Seat (Male)	Urinal Seat (Female)
CT (Community Toilet Project)	2	2	2	2

Land Details

Classification	Plot No.	Jl No.	Dag No.	Khatian No.	Mouza	Possession Details (Owned by)
Bastu	1522	140	0	370/1	ISLAMPUR	

Construction Site Second Visit Report

At the time of Roof Casting - Visit Details

Visit Date	01/02/2026			
Roof Beam Top Support (16 mm dia, 4 nos.)	Rod Nos.	Diameter (mm)	Status	Remarks
	4	16	OK	OK

Roof Beam Top Support Image



Roof Beam Bottom Support
(16 mm dia, 2 nos.)

Rod Nos.	Diameter (mm)	Status	Remarks
2	16	OK	OK

Roof Beam Bottom Support Image



Roof Beam Mid Span Top Support
(16 mm dia 2 nos)

Rod Nos.	Diameter (mm)	Status	Remarks
2	16	OK	OK


Roof Beam Mid Span Top Support Image



Roof Beam Mid Span Bottom Support
(16 mm dia 4 nos)

Rod Nos.	Diameter (mm)	Status	Remarks
4	16	OK	OK

eam Mid Span Bottom Support Image



Roof Details Parameters
(8 mm dia 125 nos)

Diameter (mm)	Depth (mm)	Status	Remarks
8	125	OK	OK

Roof Details Parameters Image



Binder for Roof Beam Support (250mm X 250mm)

Status	Remarks
OK	OK

Binder for Roof Beam Mid Span Support

Status	Remarks
OK	OK

Binder for Roof 8mm dia 125mm C/C

Status	Remarks
OK	OK

Overall Reamrks

Ok

Overall Work Status - Images

1 - Angle 1



Photo 2 - Angle 2



Signatures & Approval

SAE

SAE
Dubrajpur Municipality
Dubrajpur, Birbhum

Seal with signature of ULB Engineer
 Name: Sayed Saifuddin
 Contact no.: 9749987575

Checked & Verified
 Suprimo Ghosh
 Engineer (Civil)
 Hilli INSPIRATION

Signature of Engineer
 HILLI INSPIRATION
 Name: 8622025848
 Contact no.: SUPRIMO GHOSH

[Signature]

Signature of Co-Ordinator
 HILLI INSPIRATION
 HILLI INSPIRATION