



BIRNAGAR MUNICIPALITY

CONSTRUCTION SITE SECOND VISIT REPORT

Second Visit : PROP-00103 - Dadwasmandir

Location Details

Name of the Location	Latitude & Longitude	Ward	Area	Area Unit
Dadwasmandir	22.579696 88.413506	4	57.75	Sq/Meter





Project Details

Proposed Project Type	Toilet Seat (Male)	Toilet Seat (Female)	Urinal Seat (Male)	Urinal Seat (Female)
PT (Public Toilet Project)	2	3	2	3

Land Details

Classification	Plot No.	Jl No.	Dag No.	Khatian No.	Mouza	Possession Details (Owned by)
Other	1803	19	1803	2257	BIRNAGAR	

At the time of Roof Casting - Visit Details

Visit Date	24/02/2026			
Roof Beam Top Support (16 mm dia, 4 nos.)	Rod Nos.	Diameter (mm)	Status	Remarks
	4	16	OK	OK
Roof Beam Top Support Image				
Roof Beam Bottom Support (16 mm dia, 2 nos.)	Rod Nos.	Diameter (mm)	Status	Remarks
	2	16	OK	OK
Roof Beam Bottom Support Image				
Roof Beam Mid Span Top Support (16 mm dia 2 nos)	Rod Nos.	Diameter (mm)	Status	Remarks
	2	16	OK	OK
Roof Beam Mid Span Top Support image				
Roof Beam Mid Span Bottom Support (16 mm dia 4 nos)	Rod Nos.	Diameter (mm)	Status	Remarks
	4	16	OK	OK
Roof Beam Mid Span Bottom Support image				
Roof Details Parameters (8 mm dia 125 nos)	Diameter (mm)	Depth (mm)	Status	Remarks
	8	125	OK	OK



Binder for Roof Beam Support (250mm X 250mm)

Status	Remarks
OK	OK

Binder for Roof Beam Mid Span Support

Status	Remarks
OK	OK

Binder for Roof 8mm dia 125mm C/C

Status	Remarks
OK	OK

Overall Remarks

Ok

Overall Work Status - Images

Photo 1 - Angle 1



Photo 2 - Angle 2



Signatures & Approval

[Handwritten Signature]
24.02.26,

Seal with signature of UCB Engineer
Name: **Sub-Assistent Engineer**
Contact no.: **Birnagar Municipality**
Goutam DAS
9734372916

Checked & Verified
[Handwritten Signature]
Engineer (Civil)
Hilli INSPIRATION

Signature of Engineer
HILLI INSPIRATION
Name: **SUPREMO GHOSH**
Contact no.: **8622075848**

[Handwritten Signature]
Co-ordinator
Hilli INSPIRATION

Signature of Co-Ordinator
HILLI INSPIRATION