



HABRA MUNICIPALITY

CONSTRUCTION SITE SECOND VISIT REPORT

Second Visit : PROP-00272 - JANATA SANGHA, I.C.D.S SCHOOL

Location Details

Name of the Location	Latitude & Longitude	Ward	Area	Area Unit
JANATA SANGHA, I.C.D.S SCHOOL	22.579699 88.4135293	19	0.0035	Acre



Project Details

Proposed Project Type	Toilet Seat (Male)	Toilet Seat (Female)	Urinal Seat (Male)	Urinal Seat (Female)
PT (Public Toilet Project)	2	1	2	1

Land Details

Classification	Plot No.	Jl No.	Dag No.	Khatian No.	Mouza	Possession Details (Owned by)
Bastu	NA	72	1977	912	ASRAFABAD	

Construction Site Second Visit Report

At the time of Roof Casting - Visit Details											
Visit Date	27/04/2026										
Roof Beam Top Support (16 mm dia, 4 nos.)	<table border="1"><thead><tr><th>Rod Nos.</th><th>Diameter (mm)</th><th>Status</th><th>Remarks</th></tr></thead><tbody><tr><td>4</td><td>16</td><td>OK</td><td>OK</td></tr></tbody></table>	Rod Nos.	Diameter (mm)	Status	Remarks	4	16	OK	OK		
Rod Nos.	Diameter (mm)	Status	Remarks								
4	16	OK	OK								
Roof Beam Top Support Image											
Roof Beam Bottom Support (16 mm dia, 2 nos.)	<table border="1"><thead><tr><th>Rod Nos.</th><th>Diameter (mm)</th><th>Status</th><th>Remarks</th></tr></thead><tbody><tr><td>2</td><td>16</td><td>OK</td><td>OK</td></tr></tbody></table>	Rod Nos.	Diameter (mm)	Status	Remarks	2	16	OK	OK		
Rod Nos.	Diameter (mm)	Status	Remarks								
2	16	OK	OK								
Roof Beam Bottom Support Image											



Roof Beam Mid Span Top Support
(16 mm dia 2 nos)

Rod Nos.	Diameter (mm)	Status	Remarks
2	16	OK	OK


Roof Beam Mid Span Top Support Image



Roof Beam Mid Span Bottom Support
(16 mm dia 4 nos)

Rod Nos.	Diameter (mm)	Status	Remarks
4	16	OK	OK

Roof Beam Mid Span Bottom Support Image



Roof Details Parameters
(8 mm dia 125 nos)

Diameter (mm)	Depth (mm)	Status	Remarks
8	125	OK	OK

Roof Details Parameters Image



Binder for Roof Beam Support (250mm X 250mm)

Status	Remarks
OK	OK

Binder for Roof Beam Mid Span Support

Status	Remarks
OK	OK

Binder for Roof 8mm dia 125mm C/C

Status	Remarks
OK	OK

Overall Remarks


Ok

Overall Work Status - Images

Angle 1



Photo 2 - Angle 2



Signatures & Approval

Sub-Assistant Engineer
HABRA MUNICIPALITY

Seal with signature of ULB Engineer
Name: _____
Contact no.: _____

Checked & Verified

Engineer (Civil)
Hijli INSPIRATION

Signature of Engineer
HILLI INSPIRATION

Name: _____
Contact no.: _____

Co-ordinator
Hijli INSPIRATION

Signature of Co-Ordinator
HILLI INSPIRATION

[Download PDF](#)

