



ENGLISH BAZAR MUNICIPALITY
CONSTRUCTION SITE SECOND VISIT REPORT

Second Visit : PROP-00359 - D N Saha Vidyabhavan

Location Details

Name of the Location	Latitude & Longitude	Ward	Area	Area Unit
D N Saha Vidyabhavan	22.5797301 88.4135018	18	21.05	Sq/Meter

Project Details

Proposed Project Type	Toilet Seat (Male)	Toilet Seat (Female)	Urinal Seat (Male)	Urinal Seat (Female)
Institutional Toilet Block	4	2	5	2

Land Details

Classification	Plot No.	Jl No.	Dag No.	Khatian No.	Mouza	Possession Details (Owned by)
Danga	2648	66	2648	32	Maheshmati	

At the time of Roof Casting - Visit Details

Visit Date	10/12/2025			
Roof Beam Top Support (16 mm dia, 4 nos.)	Rod Nos.	Diameter (mm)	Status	Remarks
	4	16	OK	OK
Roof Beam Top Support Image				
Roof Beam Bottom Support (16 mm dia, 2 nos.)	Rod Nos.	Diameter (mm)	Status	Remarks
	2	16	OK	OK
Roof Beam Bottom Support Image				
Roof Beam Mid Span Top Support (16 mm dia 2 nos)	Rod Nos.	Diameter (mm)	Status	Remarks
	2	16	OK	OK
Roof Beam Mid Span Top Support Image				
Roof Beam Mid Span Bottom Support (16 mm dia 4 nos)	Rod Nos.	Diameter (mm)	Status	Remarks
	4	16	OK	OK
Roof Beam Mid Span Bottom Support Image				



Binder for Roof Beam Support (250mm X 250mm)

Status

Remarks

OK

OK

Binder for Roof Beam Mid Span Support

Status

Remarks

OK

OK

Binder for Roof 8mm dia 125mm C/C

Status

Remarks

OK

OK

Overall Remarks

Okay

Overall Work Status - Images

Photo 1 - Angle 1



Photo 2 - Angle 2



Signatures & Approval

Md. Mainuddin

ENGINEER (C) E (C) MALDA
 E. B. M.; Malda

Seal with signature of ULB Engineer

Name: *Md. Mainuddin*

Contact no.: *8250988761*

Checked & Verified

Ayub Khan
 13.12.25
 Engineer (Civil)
 HILLI INSPIRATION

Signature of Engineer

HILLI INSPIRATION

Name: _____

Contact no.: _____

Md. Mainuddin
 Co-ordinator
 HILLI INSPIRATION