



ENGLISH BAZAR MUNICIPALITY
CONSTRUCTION SITE SECOND VISIT REPORT

Second Visit : PROP-00436 - Barlow Girl's High School

Location Details

Name of the Location	Latitude & Longitude	Ward	Area	Area Unit
Barlow Girl's High School	22.5797238 88.4135317	8	21.25	Sq/Meter

Project Details

Proposed Project Type	Toilet Seat (Male)	Toilet Seat (Female)	Urinal Seat (Male)	Urinal Seat (Female)
Institutional Toilet Block	2	4	2	3

Land Details

Classification	Plot No.	Jl No.	Dag No.	Khatian No.	Mouza	Possession Details (Owned by)
Bastu	184/306	68	184/306	591	Mokdumpur	

At the time of Roof Casting - Visit Details

Visit Date	26/02/2026										
Roof Beam Top Support (16 mm dia, 4 nos.)	<table border="1"> <thead> <tr> <th>Rod Nos.</th> <th>Diameter (mm)</th> <th>Status</th> <th>Remarks</th> </tr> </thead> <tbody> <tr> <td>4</td> <td>16</td> <td>OK</td> <td>OK</td> </tr> </tbody> </table>	Rod Nos.	Diameter (mm)	Status	Remarks	4	16	OK	OK		
Rod Nos.	Diameter (mm)	Status	Remarks								
4	16	OK	OK								
Roof Beam Top Support Image											
Roof Beam Bottom Support (16 mm dia, 2 nos.)	<table border="1"> <thead> <tr> <th>Rod Nos.</th> <th>Diameter (mm)</th> <th>Status</th> <th>Remarks</th> </tr> </thead> <tbody> <tr> <td>2</td> <td>16</td> <td>OK</td> <td>OK</td> </tr> </tbody> </table>	Rod Nos.	Diameter (mm)	Status	Remarks	2	16	OK	OK		
Rod Nos.	Diameter (mm)	Status	Remarks								
2	16	OK	OK								
Roof Beam Bottom Support Image											
Roof Beam Mid Span Top Support (16 mm dia 2 nos)	<table border="1"> <thead> <tr> <th>Rod Nos.</th> <th>Diameter (mm)</th> <th>Status</th> <th>Remarks</th> </tr> </thead> <tbody> <tr> <td>2</td> <td>16</td> <td>OK</td> <td>OK</td> </tr> </tbody> </table>	Rod Nos.	Diameter (mm)	Status	Remarks	2	16	OK	OK		
Rod Nos.	Diameter (mm)	Status	Remarks								
2	16	OK	OK								
Roof Beam Mid Span Top Support Image											
Roof Beam Mid Span Bottom Support (16 mm dia 4 nos)	<table border="1"> <thead> <tr> <th>Rod Nos.</th> <th>Diameter (mm)</th> <th>Status</th> <th>Remarks</th> </tr> </thead> <tbody> <tr> <td>4</td> <td>16</td> <td>OK</td> <td>OK</td> </tr> </tbody> </table>	Rod Nos.	Diameter (mm)	Status	Remarks	4	16	OK	OK		
Rod Nos.	Diameter (mm)	Status	Remarks								
4	16	OK	OK								
Roof Beam Mid Span Bottom Support Image											

Parameters Image



Blinder for Roof Beam Support (250mm X 250mm)

Status

Remarks

OK

OK

Blinder for Roof Beam Mid Span Support

Status

Remarks

OK

OK

Blinder for Roof 8mm dia 125mm C/C

Status

Remarks

OK

OK

Overall Remarks

Ok

Overall Work Status - Images

Photo 1 - Angle 1




Photo 2 - Angle 2



Signatures & Approval

[Signature]
 SAE (C)
 English Bazar Municipality
 MALDA

Seal with signature of ULB Engineer
 Name: Soumen dora Nath Das.
 Contact no.: 9434206589.

[Signature]
 CO-ordinator
 HILLI INSPIRATION

Checked & Verified
[Signature]
 Engineer (Civil)
 HILLI INSPIRATION

Signature of Engineer
 HILLI INSPIRATION
 Name: _____
 Contact no.: _____