



HALISAHAR MUNICIPALITY

CONSTRUCTION SITE SECOND VISIT REPORT

Second Visit : PROP-00532 - NABA BHARATI G.S.F.P SCHOOL, ACHARJEE PARA HALISAHAR NORTH 24 PARGANAS, PIN-743134

Location Details

Name of the Location	Latitude & Longitude	Ward	Area	Area Unit
NABA BHARATI G.S.F.P SCHOOL, ACHARJEE PARA HALISAHAR NORTH 24 PARGANAS, PIN-743134	22.5797397 88.4135612	3	55	Sq/Meter

Project Details

Proposed Project Type	Toilet Seat (Male)	Toilet Seat (Female)	Urinal Seat (Male)	Urinal Seat (Female)
Bastu	2	2	3	2

Land Details

Classification	Plot No.	Jl No.	Dag No.	Khatian No.	Mouza	Possession Details (Owned by)
Bastu	187	06	187	7808	HALISAHAR	

At the time of Roof Casting - Visit Details

Visit Date	31/12/2025											
Roof Beam Top Support (16 mm dia, 4 nos.)	<table border="1"> <thead> <tr> <th>Rod Nos.</th> <th>Diameter (mm)</th> <th>Status</th> <th>Remarks</th> </tr> </thead> <tbody> <tr> <td>4</td> <td>16</td> <td>OK</td> <td>OK</td> </tr> </tbody> </table>	Rod Nos.	Diameter (mm)	Status	Remarks	4	16	OK	OK			
Rod Nos.	Diameter (mm)	Status	Remarks									
4	16	OK	OK									
Roof Beam Top Support Image												
Roof Beam Bottom Support (16 mm dia, 2 nos.)	<table border="1"> <thead> <tr> <th>Rod Nos.</th> <th>Diameter (mm)</th> <th>Status</th> <th>Remarks</th> </tr> </thead> <tbody> <tr> <td>2</td> <td>16</td> <td>OK</td> <td>OK</td> </tr> </tbody> </table>	Rod Nos.	Diameter (mm)	Status	Remarks	2	16	OK	OK			
Rod Nos.	Diameter (mm)	Status	Remarks									
2	16	OK	OK									
Roof Beam Bottom Support Image												
Roof Beam Mid Span Top Support (16 mm dia 2 nos)	<table border="1"> <thead> <tr> <th>Rod Nos.</th> <th>Diameter (mm)</th> <th>Status</th> <th>Remarks</th> </tr> </thead> <tbody> <tr> <td>2</td> <td>16</td> <td>OK</td> <td>OK</td> </tr> </tbody> </table>	Rod Nos.	Diameter (mm)	Status	Remarks	2	16	OK	OK			
Rod Nos.	Diameter (mm)	Status	Remarks									
2	16	OK	OK									
Roof Beam Mid Span Top Support Image												
Roof Beam Mid Span Bottom Support (16 mm dia 4 nos)	<table border="1"> <thead> <tr> <th>Rod Nos.</th> <th>Diameter (mm)</th> <th>Status</th> <th>Remarks</th> </tr> </thead> <tbody> <tr> <td>4</td> <td>16</td> <td>OK</td> <td>OK</td> </tr> </tbody> </table>	Rod Nos.	Diameter (mm)	Status	Remarks	4	16	OK	OK			
Rod Nos.	Diameter (mm)	Status	Remarks									
4	16	OK	OK									
Roof Beam Mid Span Bottom Support Image												
Roof Details Parameters (8 mm dia 125 nos)	<table border="1"> <thead> <tr> <th>Diameter (mm)</th> <th>Depth (mm)</th> <th>Status</th> <th>Remarks</th> </tr> </thead> <tbody> </tbody> </table>	Diameter (mm)	Depth (mm)	Status	Remarks							
Diameter (mm)	Depth (mm)	Status	Remarks									

Roof Details Parameters Image



Binder for Roof Beam Support (250mm X 250mm)

Status

Remarks

OK

OK

Binder for Roof Beam Mid Span Support

Status

Remarks

OK

OK

Binder for Roof 8mm dia 125mm C/C

Status

Remarks

OK

OK

Overall Remarks


All ok

Overall Work Status - Images

Photo 1 - Angle 1



Photo 2 - Angle 2



Signatures & Approval

Seal with signature of ULB Engineer
Name : _____
Contact no. : _____

Checked & Verified
Amarendra
Engineer (Civil)
HILLI INSPIRATION

Signature of Engineer
HILLI INSPIRATION
Name : _____
Contact no. : _____

Amarendra
Co-ordinator
HILLI INSPIRATION