



## HALISAHAR MUNICIPALITY

### CONSTRUCTION SITE SECOND VISIT REPORT

Second Visit : PROP-00549 - DESHBONDHU PRATHAMIK VIDYALAYA

#### Location Details

Name of the Location	Latitude & Longitude	Ward	Area	Area Unit
DESHBONDHU PRATHAMIK VIDYALAYA	22.5797306 88.4135485	14	45	Sq/Meter

#### Project Details

Proposed Project Type	Toilet Seat (Male)	Toilet Seat (Female)	Urinal Seat (Male)	Urinal Seat (Female)
Bastu	1	1	2	1

#### Land Details

Classification	Plot No.	Jl No.	Dag No.	Khatian No.	Mouza	Possession Details (Owned by)
Bastu	20	09	20	113	BALIBHARA	

At the time of Roof Casting - Visit Details

Visit Date	11/02/2026			
Roof Beam Top Support (16 mm dia, 4 nos.)	Rod Nos.	Diameter (mm)	Status	Remarks
	4	16	OK	OK
Roof Beam Top Support Image				
Roof Beam Bottom Support (16 mm dia, 2 nos.)	Rod Nos.	Diameter (mm)	Status	Remarks
	2	16	OK	OK
Roof Beam Bottom Support Image				
Roof Beam Mid Span Top Support (16 mm dia 2 nos)	Rod Nos.	Diameter (mm)	Status	Remarks
	2	16	OK	OK
Roof Beam Mid Span Top Support Image				
Roof Beam Mid Span Bottom Support (16 mm dia 4 nos)	Rod Nos.	Diameter (mm)	Status	Remarks
	4	16	OK	OK
Roof Beam Mid Span Bottom Support Image				
Roof Details Parameters (8 mm dia 125 nos)	Diameter (mm)	Depth (mm)	Status	Remarks



Binder for Roof Beam Support (250mm X 250mm)

Status: OK  
Remarks: OK

Binder for Roof Beam Mid Span Support

Status: OK  
Remarks: OK

Binder for Roof 8mm dia 125mm C/C

Status: OK  
Remarks: OK

Overall Remarks

OK

Photo 1 - Angle 1

Overall Work Status - Images



Photo 2 - Angle 2



Signatures & Approval

*Supriya Anil*  
**SUB. ASSISTANT ENGINEER**  
**HALISAHAR MUNICIPALITY**  
 Signature of ULB Engineer  
 Name: \_\_\_\_\_  
 Contact no.: \_\_\_\_\_

**Checked & Verified**  
*Supriya Anil*  
**Engineer (Civil)**  
**Hijli INSPIRATION**

Signature of Engineer  
 HILL INSPIRATION  
 Name: **SUPRIMO ANIL**  
 Contact no.: **8622075838**

Page 3 of 3  
*M. S. S.*  
**Co-ordinator**  
**Hijli INSPIRATION**