



ENGLISH BAZAR MUNICIPALITY  
CONSTRUCTION SITE SECOND VISIT REPORT

Second Visit : PROP-00669 - Ramkrishna Vidyabhaban Primary School

Location Details

Name of the Location	Latitude & Longitude	Ward	Area	Area Unit
Ramkrishna Vidyabhaban Primary School	22.5797205 88.4135065	18	25.56	Sq/Meter

Project Details

Proposed Project Type	Toilet Seat (Male)	Toilet Seat (Female)	Urinal Seat (Male)	Urinal Seat (Female)
Institutional Toilet Block	1	1	2	1

Land Details

Classification	Plot No.	Jl No.	Dag No.	Khatian No.	Mouza	Possession Details (Owned by)
Other	1977	63	1977	165, 2416, 3213	Sherpur Mokimpur	

At the time of Roof Casting - Visit Details

Visit Date 10/12/2025


Roof Beam Top Support (16 mm dia, 4 nos.)	Rod Nos.	Diameter (mm)	Status	Remarks
	4	16	OK	OK

Roof Beam Top Support Image



Roof Beam Bottom Support (16 mm dia, 2 nos.)	Rod Nos.	Diameter (mm)	Status	Remarks
	2	16	OK	OK

Roof Beam Bottom Support Image



Roof Beam Mid Span Top Support (16 mm dia 2 nos)	Rod Nos.	Diameter (mm)	Status	Remarks
	2	16	OK	OK

Roof Beam Mid Span Top Support Image




Roof Beam Mid Span Bottom Support (16 mm dia 4 nos)	Rod Nos.	Diameter (mm)	Status	Remarks
	4	16	OK	OK

Roof Beam Mid Span Bottom Support Image



Roof Details Parameters (8 mm dia 125 nos)	Diameter (mm)	Depth (mm)	Status	Remarks
---	---------------	------------	--------	---------



Binder for Roof Beam Support (250mm X 250mm)

Status

Remarks

OK

OK

Binder for Roof Beam Mid Span Support

Status

Remarks

OK

OK

Binder for Roof 8mm dia 125mm C/C

Status

Remarks

OK

OK

Overall Remarks

Ok

Overall Work Status - Images

Photo 1 - Angle 1




Photo 2 - Angle 2



Signatures & Approval

*Md: Mainuddin*

S. A. E. (C)  
E. B. M. Malda

Seal with signature of ULB Engineer

Name: *md. mainuddin*

Contact no.:

*8250 988761*

Checked & Verified

*Shayamdas*  
13.12.25  
Engineer (Civil)

Signature of Engineer

HILL INSPIRATION

Name:

Contact no.:

*Md*

Co-ordinator  
HILL INSPIRATION