



ENGLISH BAZAR MUNICIPALITY
CONSTRUCTION SITE SECOND VISIT REPORT

Second Visit : PROP-00699 - Madhabnagar Near Sampa Sishu Uddyan

Location Details

| Name of the Location | Latitude & Longitude | Ward | Area | Area Unit |
|-------------------------------------|-------------------------|------|-------|-----------|
| Madhabnagar Near Sampa Sishu Uddyan | 22.579722 88.4135243 | 1 | 21.25 | Sq/Meter |

Project Details

| Proposed Project Type | Toilet Seat (Male) | Toilet Seat (Female) | Urinal Seat (Male) | Urinal Seat (Female) |
|----------------------------|--------------------|----------------------|--------------------|----------------------|
| PT (Public Toilet Project) | 1 | 1 | 2 | 1 |

Land Details

| Classification | Plot No. | Jl No. | Dag No. | Khatian No. | Mouza | Possession Details (Owned by) |
|----------------|----------|--------|---------|-------------|-----------|-------------------------------|
| Other | 588 | 92 | 588 | 589 | Maheshpur | |

At the time of Roof Casting - Visit Details

| Visit Date | 10/12/2025 | | | | | | | | |
|--|--|---------------|---------------|--------|---------|---|----|----|----|
| Roof Beam Top Support (16 mm dia, 4 nos.) | <table border="1"> <thead> <tr> <th>Rod Nos.</th> <th>Diameter (mm)</th> <th>Status</th> <th>Remarks</th> </tr> </thead> <tbody> <tr> <td>4</td> <td>16</td> <td>OK</td> <td>OK</td> </tr> </tbody> </table> | Rod Nos. | Diameter (mm) | Status | Remarks | 4 | 16 | OK | OK |
| Rod Nos. | Diameter (mm) | Status | Remarks | | | | | | |
| 4 | 16 | OK | OK | | | | | | |
| Roof Beam Top Support Image | | | | | | | | | |
| Roof Beam Bottom Support (16 mm dia, 2 nos.) | <table border="1"> <thead> <tr> <th>Rod Nos.</th> <th>Diameter (mm)</th> <th>Status</th> <th>Remarks</th> </tr> </thead> <tbody> <tr> <td>2</td> <td>16</td> <td>OK</td> <td>OK</td> </tr> </tbody> </table> | Rod Nos. | Diameter (mm) | Status | Remarks | 2 | 16 | OK | OK |
| Rod Nos. | Diameter (mm) | Status | Remarks | | | | | | |
| 2 | 16 | OK | OK | | | | | | |
| Roof Beam Bottom Support Image | | | | | | | | | |
| Roof Beam Mid Span Top Support (16 mm dia 2 nos) | <table border="1"> <thead> <tr> <th>Rod Nos.</th> <th>Diameter (mm)</th> <th>Status</th> <th>Remarks</th> </tr> </thead> <tbody> <tr> <td>2</td> <td>16</td> <td>OK</td> <td>OK</td> </tr> </tbody> </table> | Rod Nos. | Diameter (mm) | Status | Remarks | 2 | 16 | OK | OK |
| Rod Nos. | Diameter (mm) | Status | Remarks | | | | | | |
| 2 | 16 | OK | OK | | | | | | |
| Roof Beam Mid Span Top Support Image | | | | | | | | | |
| Roof Beam Mid Span Bottom Support (16 mm dia 4 nos) | <table border="1"> <thead> <tr> <th>Rod Nos.</th> <th>Diameter (mm)</th> <th>Status</th> <th>Remarks</th> </tr> </thead> <tbody> <tr> <td>4</td> <td>16</td> <td>OK</td> <td>OK</td> </tr> </tbody> </table> | Rod Nos. | Diameter (mm) | Status | Remarks | 4 | 16 | OK | OK |
| Rod Nos. | Diameter (mm) | Status | Remarks | | | | | | |
| 4 | 16 | OK | OK | | | | | | |
| Roof Beam Mid Span Bottom Support Image | | | | | | | | | |
| Roof Details Parameters (8 mm dia 125 nos) | <table border="1"> <thead> <tr> <th>Diameter (mm)</th> <th>Depth (mm)</th> <th>Status</th> <th>Remarks</th> </tr> </thead> </table> | Diameter (mm) | Depth (mm) | Status | Remarks | | | | |
| Diameter (mm) | Depth (mm) | Status | Remarks | | | | | | |

Files Parameters Image



Binder for Roof Beam Support (250mm X 250mm)

| Status | Remarks |
|--------|---------|
| OK | OK |

Binder for Roof Beam Mid Span Support

| Status | Remarks |
|--------|---------|
| OK | OK |

Binder for Roof 8mm dia 125mm C/C

| Status | Remarks |
|--------|---------|
| OK | OK |

Overall Remarks


Ok

Overall Work Status - Images

Photo 1 - Angle 1



Photo 2 - Angle 2



Signatures & Approval

Romik Roy
S A E (C)
 English Bazar Municipality
 MALDA

Seal with signature of ULB Engineer
 Name: *Romik Roy*
 Contact no.: *8509825820*

Masud
 Co-ordinator
 HILLI INSPIRATION

Checked & Verified
Asif Uddin
 Engineer (Civil)
 HILLI INSPIRATION

Signature of Engineer
 HILLI INSPIRATION
 Name: _____
 Contact no.: _____