



ENGLISH BAZAR MUNICIPALITY
CONSTRUCTION SITE SECOND VISIT REPORT

Second Visit : PROP-00704 - Near Bandh road Swad restaurant

Location Details

Name of the Location	Latitude & Longitude	Ward	Area	Area Unit
Near Bandh road Swad restaurant	22.5797135 88.4135351	2	24.53	Sq/Meter

Project Details

Proposed Project Type	Toilet Seat (Male)	Toilet Seat (Female)	Urinal Seat (Male)	Urinal Seat (Female)
PT (Public Toilet Project)	1	1	2	1

Land Details

Classification	Plot No.	Jl No.	Dag No.	Khatian No.	Mouza	Possession Details (Owned by)
Other	3086	68	3086	04	Mokdompur	

Construction Site Second Visit Report

At the time of Roof Casting - Visit Details

Visit Date

08/12/2025

Roof Beam Top Support
(16 mm dia, 4 nos.)

Rod Nos.	Diameter (mm)	Status	Remarks
4	16	OK	OK

Roof Beam Top Support Image



Roof Beam Bottom Support
(16 mm dia, 2 nos.)

Rod Nos.	Diameter (mm)	Status	Remarks
2	16	OK	OK

Roof Beam Bottom Support Image



Roof Beam Mid Span Top Support
(16 mm dia 2 nos)

Rod Nos.	Diameter (mm)	Status	Remarks
2	16	OK	OK

Roof Beam Mid Span Top Support Image



Roof Beam Mid Span Bottom Support
(16 mm dia 4 nos)

Rod Nos.	Diameter (mm)	Status	Remarks
4	16	OK	OK

Roof Beam Mid Span Bottom Support Image



Roof Details Parameters Image



Binder for Roof Beam Support (250mm X 250mm)

Status	Remarks
OK	OK

Binder for Roof Beam Mid Span Support

Status	Remarks
OK	OK

Binder for Roof 8mm dia 125mm C/C

Status	Remarks
OK	OK

Overall Remarks

The second visit has already been completed by the IFA, but the portal was not ready for the Level-2 visit entry. However, all parameters were found to be satisfactory.

Overall Work Status - Images

Photo 1 - Angle 1



Photo 2 - Angle 2



Signatures & Approval

Shibaji Sarkar

Seal with signature of ULB Engineer

Name: _____
Contact no.: 94341-86130.

S.A.E.
SARADIA ENGINEERING

Checked & Verified

Anand Das

Engineer (Civil)
HILLI INSPIRATION

Signature of Engineer
HILLI INSPIRATION

Name: _____

Majid
Co-ordinator: 12.25
HILLI INSPIRATION

