



**JANGIPUR MUNICIPALITY**  
**CONSTRUCTION SITE SECOND VISIT REPORT**

Second Visit : PROP-01685 - Garighat

**Location Details**

Name of the Location	Latitude & Longitude	Ward	Area	Area Unit
Garighat	22.5797364 88.4134732	12	22.5 SqM	Sq/Meter





**Project Details**




Proposed Project Type	Toilet Seat (Male)	Toilet Seat (Female)	Urinal Seat (Male)	Urinal Seat (Female)
CT (Community Toilet Project)	1	1	1	1

**Land Details**


Classification	Plot No.	Jl No.	Dag No.	Khatian No.	Mouza	Possession Details (Owned by)
Danga	1358	007	1358	1693	Jangipur	

At the time of Roof Casting - Visit Details

Visit Date	22/02/2026			
Roof Beam Top Support (16 mm dia, 4 nos.)	Rod Nos.	Diameter (mm)	Status	Remarks
	4	16	OK	OK
Roof Beam Top Support Image				
Roof Beam Bottom Support (16 mm dia, 2 nos.)	Rod Nos.	Diameter (mm)	Status	Remarks
	2	16	OK	OK
Roof Beam Bottom Support Image				
Roof Beam Mid Span Top Support (16 mm dia 2 nos)	Rod Nos.	Diameter (mm)	Status	Remarks
	2	16	OK	OK
Roof Beam Mid Span Top Support Image				
Roof Beam Mid Span Bottom Support (16 mm dia 4 nos)	Rod Nos.	Diameter (mm)	Status	Remarks
	4	16	OK	OK
Roof Beam Mid Span Bottom Support Image				

Roof Details Parameters Image					
Binder for Roof Beam Support (250mm X 250mm)	<table border="1"> <thead> <tr> <th>Status</th> <th>Remarks</th> </tr> </thead> <tbody> <tr> <td>OK</td> <td>OK</td> </tr> </tbody> </table>	Status	Remarks	OK	OK
Status	Remarks				
OK	OK				
Binder for Roof Beam Mid Span Support	<table border="1"> <thead> <tr> <th>Status</th> <th>Remarks</th> </tr> </thead> <tbody> <tr> <td>OK</td> <td>OK</td> </tr> </tbody> </table>	Status	Remarks	OK	OK
Status	Remarks				
OK	OK				
Binder for Roof 8mm dia 125mm C/C	<table border="1"> <thead> <tr> <th>Status</th> <th>Remarks</th> </tr> </thead> <tbody> <tr> <td>OK</td> <td>OK</td> </tr> </tbody> </table>	Status	Remarks	OK	OK
Status	Remarks				
OK	OK				
Overall Remarks	There is no mid beam in CT 1 model drawing				
<b>Overall Work Status - Images</b>					
Photo 1 - Angle 1					
Photo 2 - Angle 2					

Signatures & Approval



Sub-Asst. Engineer  
Jangipur Municipality



Page 3 of 3-ordinator  
Hijli INSPIRATION

Checked & Verified

  
Engineer (Civil)  
Hijli INSPIRATION