

Annexure-III

Site Inspection Report for construction of CT/PT

| | | | |
|--|---|---|-------------------|
| ULB Name | GOBARDANGA MUNICIPALITY | | Date : 26.09.2024 |
| Ward No | 04 | | |
| Name of the proposed site | GOSTHA BEHARI MELA GROUND | | |
| Address | GOBARDANGA. | | |
| Category CT/PT | PT | | |
| Necessary Land Details | Wheather the Land is belonging to the ULB/Other (If Other please specify) | YES | |
| | Dag No., Khatian No., J.L. No. & other plot information. | DAG.NO- 118, KH.NO-189,544.609, MOUZA-GOBARDANGA, J.L.NO-161. | |
| | No objection Certificate received from the concerned authority (Yes/No) | YES | |
| Nearest location of CT/PT (approx. distance in meter) | 300 MTR. | | |
| Proposed no of Toilet seats | Male | 2 | |
| | Female | 2 | |
| Proposed no of Urinal seats | Male | 3 | |
| | Female | 2 | |
| To be constructed as Aspirational Toilet or Normal Toilet (only) | Aspirational/Normal | NORMAL | |
| Area required for Public Toilets | 4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m | 7.0m x 5.10m | |
| Area requirement details in sq mm for Community Toilets | Toilet Cubical (Optimum=900x1200, Minimum=750x900) | M=1200x1000mm. F=1600X1200mm | |
| | Urinal (Minimum=500x600) | 600/500 | |
| Space identified for installation of Soakpit and Soak Well | YES | | |
| Availability of surface water/piped water supply (in details) | YES | | |
| Operation and Maintenance plan in detail | Third party. | | |
| Remarks if any: | | | |
| Representative assigned from Hijli Inspiration for the site inspection | Name & Designation | PRABIR MUKHERJEE | |
| | Contact No | 9339875575 | |
| | Signature with Seal | | |
| Representative assigned from the ULB for the site inspection | Name & Designation | JUDHISTHIR PAUL. (S. A. E.) | |
| | Contact No | 9735246513 | |
| | Signature with Seal | | |



Checked & Verified
Prabir Mukherjee 16/9/24
 Engineer (Civil)
 Hijli INSPIRATION

[Signature]
 Sub-Assistant Engineer
 Gobardanga Municipality
 North 24 Parganas