

Annexure-III

Site Inspection Report for construction of CT/PT

Date : 26.09.2024

ULB Name GOBARDANGA MUNICIPALITY

Ward No 15

Name of the proposed site Chanditala Ghat in ward no.15

Address KHANTURA CHANDITALA

Category CT/PT PT

Necessary Land Details

Whether the Land is belonging to the ULB/Other (If Other please specify)

YES

Dag No., Khatian No., J.L. No. & other plot information.

DAG.NO-476 , KH.NO-875 . MOUZA- KHANTURA, J.L.NO-165 .

No objection Certificate received from the concerned authority (Yes/No)

YES

Nearest location of CT/PT (approx distance in meter)

400M

Proposed no of Toilet seats

Male

2

Female

2

Proposed no of Urinal seats

Male

3

Female

2

To be constructed as Aspirational Toilet or Normal Toilet (only)

Aspirational/Normal

NORMAL

Area required for Public Toilets

4 to 5 sq. meters per 10 toilet seats:
Min. 1.5 m x 1.2 m

7.0m x 5.10m

Area requirement details in sq mm for Community Toilets

Toilet Cubical (Optimum=900x1200,
Minimum=750x900)

M=1200x1000mm. F=1600X1200mm

Urinal (Minimum=500x600)

600/500

Space identified for installation of Soakpit and Soak Well

YES

Availability of surface water/piped water supply (in details)

YES

Operation and Maintenance plan in detail

Third party.

Remarks if any:

Representative assigned from Hijli Inspiration for the site inspection

Name & Designation

PRABIR MUKHERJEE

Contact No

9339875575

Signature with Seal

Representative assigned from the ULB for the site inspection

Name & Designation

JUDHISTHIR PAUL. (S. A. E.)

Contact No

9735246513

Signature with Seal



Checked & Verified
Prabir Mukherjee
 Engineer (Civil) 26/9/24
 Hijli INSPIRATION

Judhisthir Paul
 Sub-Assistant Engineer
 Gobardanga Municipality
 North 24 Parganas