



## Annexure-III

## Site Inspection Report for construction of CT/PT

Date: 06.02.25

ULB Name	old Malda	
Ward No	08	
Name of the proposed site	Hadden pana charak Math	
Address	Bachamani, old Malda	
Category CT/PT	PT	
Necessary Land Details	Whether the Land is belongs to the ULB/Other (If Other please specify)	Club
	Dag No., Khatian No., J.L. No. & other plot information.	Plot-236 JL-104 KH-653
	No objection Certificate received from the concerned authority	Yes
Nearest location of CT/PT (approx distance in meter)	NO	
Proposed no of Toilet seats	Male	1
	Female	1
Proposed no of Urinal seats	Male	2
	Female	1
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal	Normal
Area required for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	22.5 Sqm (model → E)
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	1000 X 1200
	Urinal (Minimum=500x600)	500 X 600
Space identified for installation of Soakpit and Soak Well	Yes	
Availability of surface water/piped water supply (in details)	Piped water	
Operation and Maintenance plan in detail	club	
Remarks if any:		
Representative assigned from Hijli Inspiration for the site inspection	Name & Designation	ABHIK MAJUMDAR (Enggr.)
	Contact No	9851301709 <b>Checked &amp; Verified</b>
	Signature with Seal	 <b>Engineer (Civil) HIJLI INSPIRATION</b>
Representative assigned from the ULB for the site inspection	Name & Designation	Sanku Bhattacharya (Nodal Enggr. SPM)
	Contact No	9800026306
	Signature with Seal	 <b>SENIOR ENGINEER SPM</b>

Malda Municipality