



## Annexure-III

## Site Inspection Report for construction of CT/PT

Date: 06.02.25

ULB Name	old Malda	
Ward No	08	
Name of the proposed site	Bachamani Govt. colony Field	
Address	Bachamati, old Malda.	
Category CT/PT	PT	
Necessary Land Details	Whether the Land is belongs to the ULB/Other (If Other please specify)	Club
	Dag No., Khatian No., J.L. No. & other plot information.	Plot-661 SL-104 Kh-561
	No objection Certificate received from the concerned authority	Yes
Nearest location of CT/PT (approx distance in meter)	NO	
Proposed no of Toilet seats	Male	2
	Female	2
Proposed no of Urinal seats	Male	3
	Female	2
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal	NORMAL
Area required for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	35.7 Sqm (Model-67)
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	1000x1200
	Urinal (Minimum=500x600)	500x600
Space identified for installation of Soakpit and Soak Well	Yes	
Availability of surface water/piped water supply (in details)	Piped water	
Operation and Maintenance plan in detail	Club	
Remarks if any:		
Representative assigned from Hijli Inspiration for the site inspection	Name & Designation	ABHIK MAJUMDAR (Engg.)
	Contact No	9851301709
	Signature with Seal	 Engg. Hiji Inspiration
Representative assigned from the ULB for the site inspection	Name & Designation	Sanku Bhattacharya (Nodal Engine. SPM)
	Contact No	9800026306
	Signature with Seal	 ENGINEER SPM Malda Municipality

Malda Municipality