

Annexure-III

Site Inspection Report for construction of CT/PT

Date: 03/01/2025

ULB Name	Barrackpore Municipality	
Ward No	16	
Name of the proposed site	Chaimath	
Address	Munsi Mondal Road	
Category CT/PT		
Necessary Land Details	Wheather the Land is belongs to the ULB/Other (If Other please specify)	Yes
	Dag No., Khatian No., J.L. No. & other plot information.	DL No: 5, Dag No: 2975, Khatian No: 727, Mouza' Titagarh
	No objection Certificate received from the concerned authority (Yes/No)	Yes
Nearest location of CT/PT (approx distance in meter)	650m	
Proposed no of Toilet seats	Male	2
	Female	3
Proposed no of Urinal seats	Male	2
	Female	3
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal	Normal
Area rquired for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	7.5m X 7.7 m
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	Male- 1200x 1000mm Female-1800 x1000mm
	Urinal (Minimum=500x600)	600 x 500mm
Space identified for installation of Soakpit and Soak Well	Nil	
Availability of surface water/piped water supply (in details)	Municipal Water Connection	
Operation and Maintenance plan in detail	Community/ULB	
Remarks if any:	As per Community Toilet Model No. A	
Representative assigned from Hijli Inspiration for the site inspection	Name & Designation	
	Contact No	9333875575 Checked & Verified
	Signature with Seal	<i>Srijibesh Chatterjee</i> Engineer (Civil)
Representative assigned from the ULB for the site inspection	Name & Designation	Srijibesh Chatterjee (SAE), Sudip Saha Hijli INSPIRATION
	Contact No	8697564832
	Signature with Seal	

K Roy
Kausik Roy
Assistant Engineer
Barrackpore Municipality

Srijibesh Chatterjee
Executive Officer
Barrackpore Municipality