

Annexure-III

Site Inspection Report for construction of CT/PT

B Name		Date :24/10/2024	
Ward No		KONNAGAR MUNICIPALITY	
Name of the proposed site		11	
Address		Sec. Konnagar Dwadas Mandir Ghat	
Category CT/PT		21. G.T Road(EAST)	
Necessary Land Details		PT	
Wheatear the Land is belongs to the ULB/Other (If Other please specify)		ULB	
Dag No., Khatian No., J.L. No. & other plot information.		Dag No.-7281&7282, Khatian No.-, J.L. No.-7 & Area.-46Katha 00Chatak	
No objection Certificate received from the concerned authority (Yes/No)		Yes	
Nearest location of CT/PT (approx. distance in meter)		800 mtr	
Proposed no of Toilet seats	Male	1	
	Female	1	
Proposed no of Urinal seats	Male	2	
	Female	1	
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal	Aspirational F	
Area required for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	5 m X 4.5m	
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	1200 x 1000	
	Urinal (Minimum=500x600)	500x600	
Space identified for installation of Soak pit and Soak Well		Yes	
Availability of surface water/piped water supply (in details)		Yes	
Operation and Maintenance plan in detail		Maintenance by ULB	
Remarks if any:			
Representative assigned from Hijli Inspiration for the site inspection	Name & Designation	SHAHID ANWAR	
	Contact No	7980028462	
	Signature with Seal		
Representative assigned from the ULB for the site inspection	Name & Designation	KOUSHIK MONDAL (S.A.E)	
	Contact No	7688079640	
	Signature with Seal	K Mondal SAE Konnagar Municipality	

S. Chakraborty
Executive Officer
Konnagar Municipality

S. Mondal & Verified
Engineer (Civil)
Hijli INSPIRATION

K. Mondal
Chairman
Konnagar Municipality