




## Site Inspection Report for construction of CT/PT

Date: 20/03/2025

ULB Name	Dalkhola Municipality	
Ward No	28	
Name of the proposed site	Dalkhola Bazar	
Address	Dalkhola	
Category CT/PT	PT	
Necessary Land Details	Whether the Land is belongs to the ULB/Other (If Other please specify)	ULB
	Dag No., Khatian No., J.L. No. & other plot information.	Mouza - Dalkhola, JL no- 20, Plot No-1
	No objection Certificate received from the concerned authority (Yes/No)	Yes
Nearest location of CT/PT (approx distance in meter)		100 m $\square$
Proposed no of Toilet seats	Male	2
	Female	2
Proposed no of Urinal seats	Male	3
	Female	2
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal	Normal
Area required for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	35.7 Sq.m (Model-6)
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	
	Urinal (Minimum=500x600)	
Space identified for installation of Soak pit and Soak Well		Yes
Availability of surface water/piped water supply (in details)		No water
Operation and Maintenance plan in detail		ULB
Remarks if any:	Pump needed	
Representative assigned from Hijli Inspiration for the site inspection	Name & Designation	Abhik Majumdar (Civil Engineer)
	Contact No	9851301709 & Verified
	Signature with Seal	 Engineer (Civil) Hijli INSPIRATION
Representative assigned from the ULB for the site inspection	Name & Designation	Bhabani Shankar Dhal
	Contact No	9614331397
	Signature with Seal	 Sub-Asst. Engineer Dalkhola Municipality
		 Chairman Dalkhola Municipality

Sub-Asst. Engineer  
Dalkhola MunicipalityChairman  
Dalkhola Municipality