



Annexure-III		
Site Inspection Report for construction of CT/PT		
		Date :
ULB Name	Murshidabad Municipality	
Ward No	2	
Name of the proposed site	Lalbagh Burning Ghat	
Address	Ward - 2, Lalbagh Burning Ghat, Murshidabad, Pin- 742149	
Category CT/PT	PT	
Necessary Land Details	Whether the Land is belongs to the ULB/Other (If Other please specify)	Other
	Dag No., Khatian No., J.L. No. & other plot information.	Dag No 489, Khatian No 1094, J.L. No 44, Mouza - lalbagh
	No objection Certificate received from the concerned authority (Yes/No)	Yes
Nearest location of CT/PT (approx distance in meter)		N.A
Proposed no of Toilet seats	Male	1
	Female	1
Proposed no of Urinal seats	Male	2
	Female	1
To be constructed as Aspirational Toilet or Normal Toilet (only applicable for PTs)	Aspirational/Normal	Normal
Area rquired for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	5m X 4.5m
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	Male - 1200/1000m, Female - 1600/1200mm
	Urinal (Minimum=500x600)	600/500
Space identified for installation of Soakpit and Soak Well		Yes
Availability of surface water/piped water supply (in details)		Yes
Operation and Maintenance plan in detail		ULB
Remarks if any:		
Representative assigned from Hijli Inspiration for the site inspection	Name & Designation	Abhik Majumdar, Eng.
	Contact No	98513061709
	Signature with Seal	
Representative assigned from the ULB for the site inspection	Name & Designation	Somnath Pal, S.A.E. Engineer (Civil)
	Contact No	9382654717
	Signature with Seal	

S.A.E.
 Murshidabad Municipality

