



Annexure-III

Site Inspection Report for construction of CT/PT

Date: 06.12.24

| | | |
|--|---|---|
| ULB Name | Bhatpara | |
| Ward No | 3 | |
| Name of the proposed site | Bazarpara | |
| Address | Bazarpara, Ferry Ghat Road, Bhatpara, North 24 Parganas | |
| Category CT/PT | CT | |
| Necessary Land Details | Whether the Land is belongs to the ULB/Other (If Other please specify) | ULB |
| | Dag No., Khatian No., J.L. No. & other plot information. | Dag No.-3390(LR) |
| | No objection Certificate received from the concerned authority (Yes/No) | Yes |
| Nearest location of CT/PT (approx distance in meter) | CT | |
| Proposed no of Toilet seats | Male | 1 |
| | Female | 1 |
| Proposed no of Urinal seats | Male | 2 |
| | Female | 1 |
| To be constructed as Aspirational Toilet or Normal Toilet (only) | Aspirational/Normal Normal-'F' | |
| Area required for Public Toilets | 4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m | 22.5 Sqm |
| Area requirement details in sq mm for Community Toilets | Toilet Cubical (Optimum=900x1200, Minimum=750x900) | M-1200/1000mm, F-1600/1200mm |
| | Urinal (Minimum=500x600) | 600/500 |
| Space identified for installation of Soakpit and Soak Well | Yes | |
| Availability of surface water/piped water supply (in details) | Yes | |
| Operation and Maintenance plan in detail | ULB | |
| Remarks if any: | | |
| Representative assigned from Hijli Inspiration for the site inspection | Name & Designation | Shahid Anwar Ansari, Civil Engineer |
| | Contact No | 7980028462 & Verified |
| | Signature with Seal |  |
| Representative assigned from the ULB for the site inspection | Name & Designation | Mithun Kumar Das, S.A.E, Bhatpara Municipality |
| | Contact No | 9804989889 |
| | Signature with Seal |  |

MITHUN KUMAR DAS
Sub Asst. Engineer (Civil)
Bhatpara Municipality