

Annexure-III

Site Inspection Report for construction of CT/PT

Date :

ULB Name	HABRA	
Ward No	14	
Name of the proposed site	Habra Municipal office	
Address		
Category CT/PT	CT	
Necessary Land Details	Whether the Land is belongs to the ULB/Other (If Other please specify)	
	Dag No., Khatian No., J.L. No. & other plot information.	Dag No:- 1436, Khatian NO:- 7269, JL No:- 80 Mouza:- Hijalpa Kuria.
	No objection Certificate received from the concerned authority (Yes/No)	Yes,
Nearest location of CT/PT (approx distance in meter)	CT	
Proposed no of Toilet seats	Male	2
	Female	2
Proposed no of Urinal seats	Male	3
	Female	2
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal ✓	Normal
Area required for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	ULB Model
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	(1200 x 1000), (1200 x 1600)
	Urinal (Minimum=500x600)	(850 x 700)
Space identified for installation of Soakpit and Soak Well	Yes	
Availability of surface water/piped water supply (in details)	Yes	
Operation and Maintenance plan in detail	ULB	
Remarks if any:	ULB Model.	
Representative assigned from Hijli Inspiration for the site inspection	Name & Designation	
	Contact No	Checked & Verified 9339875525
	Signature with Seal	Phalen Khatun Engineer (Civil) Hijli INSPIRATION
Representative assigned from the ULB for the site inspection	Name & Designation	Sandeep Kumar Datta, S.A.E.
	Contact No	9474079888
	Signature with Seal	

Sub-Assistant Engineer
HABRA MUNICIPALITY



 **GPS Map Camera**

Habra, West Bengal, India
Padma Niloy, 36, Promod Dasgupta Sarani, Habra, West
Bengal 743271, India
Lat 22.839038° Long 88.652764°
25/01/25 05:17 PM GMT +05:30



Google