

Annexure-III
Site Inspection Report for construction of CT/PT




Date: 13.01.2025

ULB Name	Mirik Municipality	
Ward No	3	
Name of the proposed site	Opposite to Aquarium at Thananline	
Address	Thananline	
Category CT/PT	PT	
Necessary Land Details	Wheather the Land is belongs to the ULB/Other (If Other please specify)	ULB
	Dag No., Khatian No., J.L. No. & other plot information.	Dag No., Khatian No., J.L. No. & plot no not found
	No objection Certificate received from the concerned authority (Yes/No)	yes
Nearest location of CT/PT (approx distance in meter)		No
Proposed no of Toilet seats	Male	3
	Female	5
Proposed no of Urinal seats	Male	9
	Female	5
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal	Aspirational
Area rquired for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	14m X 11m (Model- B)
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	
	Urinal (Minimum=500x600)	
Space identified for installation of Soakpit and Soak Well		Yes
Availability of surface water/piped water supply (in details)		Piped Water
Operation and Maintenance plan in detail		ULB by PPP model
Remarks if any:	T.G donated Land	
Representative assigned from Hijli Inspiration for the site inspection	Name & Designation	Dibyendu Bhattacharjee (Co-ordinator) & Abhik Majumdar (Civil Engineer)
	Contact No	9932204505 & 9851301709 <i>Checked & Verified</i>
	Signature with Seal	<i>Sohit Chakraborty</i> <i>Abhik Majumdar</i> Engineer (Civil)
Representative assigned from the ULB for the site inspection	Name & Designation	NImasang Tamang (S.A.E) <i>MIRIK INSPIRATION</i>
	Contact No	9749071255
	Signature with Seal	<i>IS</i> Sub-Assistant Engineer Mirik Notified Area Authority





Latitude: 26.88937
 Longitude: 88.186162
 Elevation: 1618.3414 m
 Accuracy: 29.9 m
 Time: 13-01-2025 14:00
 Note: Opposite to Aquarium
 ward no. 5.

MODE DRAWING FOR CONSTRUCTION OF C. T./P.T.
 Toilet Seats - 8 Nos, Urinal 14 nos
 MODLE NO. - B



Details Of R.C.C Roof Slab & Beam
 (SCALE - 1 : 25)



[Signature]
 Sub-Assistant Engineer
 Mirik Notified Area Authority

Opposite to Aquarium at Thananline