

বাসন্তীতলা বারোয়ারী ঙ্গস্থা

হালিসহর, শিবেরগলি, বাসন্তীতলা, উত্তর ২৪ পরগণা।

স্থাপিত : ১৯৫১

Regd. No.: S/2L/8309

পত্রাঙ্ক :

তারিখ :

To
the chairman,
Halisahar Municipality
Halisahar North 24 Parganas.

Subject: Sending necessary documents for setting up
New Toilet with our Basantitale Baroyari Sanstha

Dear Sir,

I, hereby sending you all necessary documents for setting up
New Toilet within our Basantitale Baroyari Sanstha premises
through Mission Nirmal Bangla under your laudable initiative.

I, shall be highly obliged if you kindly take necessary action.

Thanking you.

**SASANTITALA BAROARI SANGSTHA
SIBER GALI, HALISAHAR**

Secretary Treasurer

Saboyasneh Ganguly

Gumpada Ganguly

Samin Ch. Das



পশ্চিমবঙ্গ পশ্চিম বঙ্গাল WEST BENGAL

36AA 530370

To
The Chairman
Halisahar Municipality
Halisahar, North 24 Parganas

Subject: 'No-Objection' for setting up Toilet Complex under Mission Nirmal Bangla scheme .

Dear Sir,

I wish to inform you that there is 'No Objection from (Basanti Tala. Ward No-6) if toilet complex is being set up under Mission Nirmal Bangla scheme as per inspected space for the benefit of the society.

Thanking You,

Santis ch. Das
President/ Sectary
(Basanti Tala. Ward No-6)

Annexure-III

Site Inspection Report for construction of CT/PT

Date: 11.09.2024

ULB Name	HALISAHAR MUNICIPALITY	
Ward No	5	
Name of the proposed site	BASANTI TALA BAROYARI SANSTHA	
Address	SIBER GOLI MAIN ROAD	
Category CT/PT	(PT)	
Necessary Land Details	Whether the Land is belongs to the ULB/Other (If Other please specify)	ULB LAND
	Dag No., Khatian No., J.L. No. & other plot information	DAG NO. RS-1382 JL NO. 06, MOUZA - HALISAHAR
	No objection Certificate received from the concerned authority	YES
Nearest location of CT/PT (approx distance in meter)	NA	
Proposed no of Toilet seats	Male	10
	Female	10
Proposed no of Urinal seats	Male	20
	Female	10
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal	Normal
Area required for Public Toilets	4 to 5 sq. meters per 10 toilet seats. Min. 15 m x 1.2 m	MODEL-F (5.0 X 4.0)
Area requirement details in sq. m for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	1200 X 1000/1600 X 1200
	Urinal (Minimum=500x600)	750 X 600
Space identified for installation of Soak pit and Soak Well	YES	
Availability of surface water/piped water supply (in details)	AVAILABLE (6.0) MTR	
Operation and Maintenance plan in detail	PUJA COMMITTEE	
Remarks if any		
Representative assigned from Hiji Inspiration for the site inspection	Name & Designation	PROBIR MUKHOPADHYAY (Civil Engineer)
	Contact No	9339875575
	Signature with Seal	
Representative assigned from the ULB for the site inspection	Name & Designation	SAIKAT BISWAS (S.A.E)
	Contact No	7980865833
	Signature with Seal	




Sub-Assistant Engineer
Halisahar Municipality

Charman,
Halisahar Municipality

Checked & Verified
Shobin Mukhopadhyay
Engineer (Civil)
Hiji INSPIRATION





BASANTI TALA