



Annexure-III

Site Inspection Report for construction of CT/PT

Date :

ULB Name	Murshidabad Municipality	
Ward No	11	
Name of the proposed site	Kurmitola Kalitola Park	
Address	Kurmitola Kalitola, Murshidabad, Pin- 742149	
Category CT/PT	PT	
Necessary Land Details	Wheather the Land is belongs to the ULB/Other (If Other please specify)	ULB
	Dag No., Khatian No., J.L. No. & other plot information.	Dag No 28, Khatian No 459, J.L. No 59, Mouza - urdu bazar
	No objection Certificate received from the concerned authority (Yes/No)	Yes
Nearest location of CT/PT (approx distance in meter)		N.A
Proposed no of Toilet seats	Male	1
	Female	1
Proposed no of Urinal seats	Male	2
	Female	1
To be constructed as Aspirational Toilet or Normal Toilet (only applicable for PTs)	Aspirational/Normal	Normal
Area rquired for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	5m X 4.5m
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	Male - 1200/1000m, Female - 1600/1200mm
	Urinal (Minimum=500x600)	600/500
Space identified for installation of Soakpit and Soak Well		Yes
Availability of surface water/piped water supply (in details)		Yes
Operation and Maintenance plan in detail		ULB
Remarks if any:		
Representative assigned from Hiji Inspiration for the site inspection	Name & Designation	Abhik Majumdar, Eng.
	Contact No	9851301709
	Signature with Seal	 Engineer (Civil)
Representative assigned from the ULB for the site inspection	Name & Designation	Somnath Pal, SAE
	Contact No	9382654717
	Signature with Seal	 S.A.E.

Murshidabad Municipality

