

Annexure-III

Site Inspection Report for construction of CT/PT

Date :

Murshidabad Municipality

ULB Name

1

Ward No

Name of the proposed site

Gulab Bagh Play Ground

Address

Gulab Bagh, Lalbagh, Murshidabad, Pin- 742149

Category CT/PT

PT

Necessary Land Details

Whether the Land is belongs to the ULB/Other (If Other please specify)

ULB

Dag No., Khatian No., J.L. No. & other plot information.

Dag No 332, Khatian No 1, J.L. No 45, Mouza - Sahanagar

No objection Certificate received from the concerned authority (Yes/No)

Yes

Nearest location of CT/PT (approx distance in meter)

N.A

Proposed no of Toilet seats

Male

2

Female

3

Proposed no of Urinal seats

Male

2

Female

3

To be constructed as Aspirational Toilet or Normal Toilet (only applicable for PTs)

Aspirational/Normal

Normal

Area required for Public Toilets

4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m

7.5m X 7.7 m

Area requirement details in sq mm for Community Toilets

Toilet Cubical (Optimum=900x1200, Minimum=750x900)

Male - 1200/1000m, Female - 1600/1200mm

Urinal (Minimum=500x600)

600/500

Space identified for installation of Soakpit and Soak Well

Yes

Availability of surface water/piped water supply (in details)

Yes

Operation and Maintenance plan in detail

ULB

Remarks if any:

Representative assigned from Hijli Inspiration for the site inspection

Name & Designation

Abhik Majumdar, Eng.

Contact No

9851301709ked & Verified

Signature with Seal

Engineer (Civil)

Representative assigned from the ULB for the site inspection

Name & Designation

Somnath Pal, SAE

Contact No

9382654717

Signature with Seal

S.A.E.

Murshidabad Municipality

