



## Annexure-III

## Site Inspection Report for construction of CT/PT

Date: 28.01.23

S.L. NO 71

ULB Name	English Bazar		
Ward No	14.		
Name of the proposed site	Banshbhari Health Center.		
Address	Ward-14, E.B.M.		
Category CT/PT	PT.		
Necessary Land Details	Whether the Land belongs to the ULB/Other (If Other please specify)	Private.	
	Dag No., Khatian No., J.L. No. & other plot information.	L.R.-3021	
	No objection Certificate received from the concerned authority	Yes.	
Nearest location of CT/PT (approx distance in meter)	NO		
Proposed no of Toilet seats	Male		
	Female		
Proposed no of Urinal seats	Male		
	Female		
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal		
Area required for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m		
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)		
	Urinal (Minimum=500x600)		
Space identified for installation of Soakpit and Soak Well	NO		
Availability of surface water/piped water supply (in details)	NA		
Operation and Maintenance plan in detail	NA		
Remarks if any:	Insufficient space.		
Representative assigned from Hijli inspiration for the site inspection	Name & Designation	Abhishek Majumdar (Engg).	
	Contact No	9851301709	
	Signature with Seal	 Engineer (Civil) Hijli INSPIRATION	
Representative assigned from the ULB for the site inspection	Name & Designation	Pranab Das, S.A.E(C), E.B.M	
	Contact No	8026551792	
	Signature with Seal	 S. A. E. (C)	



New Toilet  
Bansbari Health center  
25.01356, 88.14438  
247V+FHV, Malda 732101