



## Annexure-III

## Site Inspection Report for construction of CT/PT

Date : 06.12.24

ULB Name	Bhatpara	
Ward No	31	
Name of the proposed site	Keutia Vidya Mandir F.P. School	
Address	Keutia Charak Danga,P.O.- Keutia, Dist- North 24 Parganas,743126	
Category CT/PT	PT	
Necessary Land Details	Wheather the Land is belongs to the ULB/Other (If Other please specify)	Other
	Dag No., Khatian No., J.L. No. & other plot information.	DAG No.21
	No objection Certificate received from the concerned authority	Yes
Nearest location of CT/PT (approx distance in meter)	N/A	
Proposed no of Toilet seats	Male	1
	Female	1
Proposed no of Urinal seats	Male	2
	Female	1
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal	N - 'F' Model
Area rquired for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	22.5 Sqm
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	M-1200/1000mm, F-1600/1200mm
	Urinal (Minimum=500x600)	600/500
Space identified for installation of Soakpit and Soak Well	Yes	
Availability of surface water/piped water supply (in details)	Yes	
Operation and Maintenance plan in detail	School	
Remarks if any:		
Representative assigned from Hijli Inspiration for the site inspection	Name & Designation	Shahid Anwar Ansari, Civil Engineer
	Contact No	7980028462 Checked & Verified
	Signature with Seal	
Representative assigned from the ULB for the site inspection	Name & Designation	Mithun Kumar Das,S.A.E, Bhatpara Municipality Engineer (Civil)
	Contact No	9804989889
	Signature with Seal	

MITHUN KUMAR DAS  
Sub-Asst. Engineer (Civil)  
Bhatpara Municipality