



Annexure-III

Site Inspection Report for construction of CT/PT

Date: 18/03/25

ULB Name	Islampur	
Ward No	23	
Name of the proposed site	Shantimagan Poru Samaj Bhanan	
Address	Islampur	
Category CT/PT	PT	
Necessary Land Details	Whether the Land is belongs to the ULB/Other (If Other please specify)	ULB
	Dag No., Khatian No., J.L. No. & other plot information.	RS Plot No → 109 SL No. → 59 Mouza → Islampur
	No objection Certificate received from the concerned authority	—
Nearest location of CT/PT (approx distance in meter)		
Proposed no of Toilet seats	Male	—
	Female	—
Proposed no of Urinal seats	Male	—
	Female	—
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal	—
Area required for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	— (Cancel)
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	—
	Urinal (Minimum=500x600)	—
Space identified for installation of Soakpit and Soak Well	—	
Availability of surface water/piped water supply (in details)	—	
Operation and Maintenance plan in detail	—	
Remarks if any:	Cancel due to insufficient space & near to Pond.	
Representative assigned from Hijli Inspiration for the site inspection	Name & Designation	ABHIK MAJUMDAR (Eng.)
	Contact No	9851301709
	Signature with Seal	
Representative assigned from the ULB for the site inspection	Name & Designation	FIROJ ALI
	Contact No	7407907441
	Signature with Seal	 (MCE)

Municipal Civil Engineer
C.L.T.C.
Islampur Municipality



New Toilet
Poro Bhaban
26.26053, 88.17880