



Annexure-III

Site Inspection Report for construction of CT/PT

Date : 06/12/24

ULB Name	Bhatpara	
Ward No	8	
Name of the proposed site	Kankinara Urdu Girls' High School (H.S.) 2nd Floor	
Address	B.L. No.-03, H/No.-16/1, P.O.- Kankinara. Dist- North 24 Parganas, PIN- 743126	
Category CT/PT	PT	
Necessary Land Details	Wheather the Land is belongs to the ULB/Other (If Other please specify)	Other
	Dag No., Khatian No., J.L. No. & other plot information.	DAG No.-2530
	No objection Certificate received from the concerned authority	Yes
Nearest location of CT/PT (approx distance in meter)	N/A	
Proposed no of Toilet seats	Male	1, 2
	Female	1, 2
Proposed no of Urinal seats	Male	2, 3
	Female	1, 2
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal	N - 'F' & 'G' Model
Area rquired for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	35.7 sqm
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	M-1200/1000mm, F-1600/1200mm
	Urinal (Minimum=500x600)	600/500
Space identified for installation of Soakpit and Soak Well	Yes	
Availability of surface water/piped water supply (in details)	Yes	
Operation and Maintenance plan in detail	School	
Remarks if any:		
Representative assigned from Hijli Inspiration for the site inspection	Name & Designation	Shahid Anwar Ansari, Civil Engineer
	Contact No	7980028462 Checked & Verified
	Signature with Seal	 Engineer (Civil) Hijli INSPIRATION
Representative assigned from the ULB for the site inspection	Name & Designation	Mithun Kumar Das, S.A.E, Bhatpara Municipality
	Contact No	9804989889
	Signature with Seal	 MITHUN KUMAR DAS Sub-Asst. Engineer (Civil) Bhatpara Municipality