

Annexure-III

Site Inspection Report for construction of CT/PT

Date: 06.02.25

ULB Name	Old Malda	
Ward No	03	
Name of the proposed site	Chandi Mandap	
Address	Dhopa Para, Malda	
Category CT/PT	PT	
Necessary Land Details	Whether the Land is belongs to the ULB/Other (If Other please specify)	Club
	Dag No., Khatian No., J.L. No. & other plot information.	Plot-340, JL-98 KH-1808
	No objection Certificate received from the concerned authority	Yes.
Nearest location of CT/PT (approx distance in meter)	No	
Proposed no of Toilet seats	Male	1
	Female	1
Proposed no of Urinal seats	Male	2
	Female	1
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal	Normal
Area required for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	22.5 sqm (Model → Provably 'F')
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	1000x1200
	Urinal (Minimum=500x600)	500x600
Space identified for installation of Soakpit and Soak Well	Yes.	
Availability of surface water/piped water supply (in details)	Yes.	
Operation and Maintenance plan in detail	Club.	
Remarks if any:	The club committee discussed if they would provide our joint inspection selected site. Then the model could be model- (F)	
Representative assigned from Hijli Inspiration for the site inspection	Name & Designation	ABHIK MAJUMDAR (Engr.)
	Contact No	9851301709 Checked & Verified
	Signature with Seal	<i>Abhimondar</i> Engineer (Civil) Hijli INSPIRATION
Representative assigned from the ULB for the site inspection	Name & Designation	Sankha Bhattacharya (Nodal Engineer SBM)
	Contact No	9807076396
	Signature with Seal	<i>Sankha Bhattacharya</i> NODAL ENGINEER SBM Old Malda Municipality