



Annexure-III

Site Inspection Report for construction of CT/PT

Date: 29/03/2025

ULB Name	Dalkhola Municipality	
Ward No	6	
Name of the proposed site	Dalkhola High School (Unit-2)	
Address	Dalkhola	
Category CT/PT	Institutional	
Necessary Land Details	Whether the Land belongs to the ULB/Other (If Other please specify)	School
	Dag No., Khatian No., J.L. No. & other plot information.	Mouza-Dalkhola, SL-20 Plot No.-1539
	No objection Certificate received from the concerned authority (Yes/No)	Yes
Nearest location of CT/PT (approx distance in meter)		
Proposed no of Toilet seats	Male	2
	Female	2
Proposed no of Urinal seats	Male	3
	Female	2
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal	Normal
Area required for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	35.7 sqm (Model-G)
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	
	Urinal (Minimum=500x600)	
Space identified for installation of Soak pit and Soak Well		Yes
Availability of surface water/piped water supply (in details)		Piped water
Operation and Maintenance plan in detail		School
Remarks if any:		
Representative assigned from Hijli Inspiration for the site inspection	Name & Designation	Abhik Majumdar (Civil Engineer)
	Contact No	9851301709
	Signature with Seal	 Engineer (Civil) Hijli INSPIRATION
Representative assigned from the ULB for the site inspection	Name & Designation	Bhabani Shankar Dhal
	Contact No	9614331397
	Signature with Seal	 Chairman

Sub-Asst. Engineer
Dalkhola MunicipalityChairman
Dalkhola Municipality