

## Annexure-III

## Site Inspection Report for construction of CT/PT

Date: 24.01.25

ULB Name	Guskara Municipality	
Ward No	3	
Name of the proposed site	Hinduathani para	
Address	Hinduathani para	
Category CT/PT	CT	
Necessary Land Details	Whether the Land is belongs to the ULB/Other (If Other please specify)	Private
	Dag No., Khatian No., J.L. No. & other plot information.	Plot - 850, Khatian - Moliya - Guskara JL NO - 158/110
	No objection Certificate received from the concerned authority (Yes/No)	Yes
Nearest location of CT/PT (approx distance in meter)	No	
Proposed no of Toilet seats	Male	1
	Female	1
Proposed no of Urinal seats	Male	2
	Female	1
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal	
Area required for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	Model - F
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	
	Urinal (Minimum=500x600)	
Space identified for installation of Soakpit and Soak Well	Yes	
Availability of surface water/piped water supply (in details)	Available	
Operation and Maintenance plan in detail	Community user group.	
Remarks if any:		
Representative assigned from Hijli Inspiration for the site inspection	Name & Designation	
	Contact No	9339875575
	Signature with Seal	
Representative assigned from the ULB for the site inspection	Name & Designation	
	Contact No	
	Signature with Seal	

24.1.25  
NODAL ENGINEER, SWM  
Guskara Municipality

Checked & Verified  
Pradeep Kumar  
Engineer (Civil)  
HIJLI INSPIRATION