



OFFICE OF THE COUNCILLORS
Jiaganj-Azimganj Municipality

P.O.-Azimganj; Dist.-Murshidabad

West Bengal; PIN-742122.

e-mail – jamunicipality@gmail.com

Phone: 03483-253222

To whom it may concern

This is to state that the undersigned has no objection if Public Toilet (P.T) is constructed at the under describe land of the Municipality.

Location- Jiaganj Nimtalaghat, Jiaganj, Murshidabad, ward no-06, Under Jiaganj-Azimganj Municipality,

Owner- Jiaganj-Azimganj Municipality.

Land Details-

Mouja: -Durgapur, J.L.No.-207,

Khatian No.-1

Plot No.-105

Land Area-40.0 Sqm.


Chairman,
Jiaganj – Azimganj Municipality
Chairman
Jiaganj-Azimganj Municipality

Annexure-III

Site Inspection Report for construction of CT/PT

Date :



Block Name	JIAGANJ-AZIMGANJ	
Ward No	6	
Name of the proposed site	Construction of Pulic Toilet (P.T) at JIAGANJ NIMTALA GHAT.	
Address	NIMTALA GHAT	
Category CT/PT	P.T	
Necessary Land Details	Wheather the Land is belongs to the ULB/Other (If Other please specify)	ULB
	Dag No., Khatian No., J.L. No. & other plot information.	Mouza with JL : DURGAPUR-207, Plot no:-105 Kh no:-1
	No objection Certificate received from the concerned authority (Yes/No)	YES
Nearest location of CT/PT	NA	
Proposed no of Toilet seats	Male	1
	Female	1
Proposed no of Urinal seats	Male	2
	Female	1
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal	NORMAL
Area rquired for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	MODEL-F (22.5 SQM)
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	1000X1200
	Urinal (Minimum=500x600)	750X600
Space identified for installation of Soakpit and Soak Well	YES	
Availability of surface water/piped water supply (in details)	YES	
Operation and Maintenance plan in detail	ULB	
Remarks if any:		
Representative assigned from Hijli Inspiration for the site inspection	Name & Designation	SHAHID ANWAR ANSARI (CIVIL ENGINEER)
	Contact No	7980028462
	Signature with Seal	
Representative assigned from the ULB for the site inspection	Name & Designation	KOUSIK PANDEY (TECHNICAL SUPERVISOR)
	Contact No	7001198093
	Signature with Seal	

Inspector & Member

Supervisor


Chairman

MODEL DRAWING FOR CONSTRUCTION OF C. T./P.T.
TOILET SEATS 2 NOS URINAL 3 NOS
MODEL NO.- F




FRONT ELEVATION



Details Of R.C.C Roof Slab & Beam
(SCALE - 1 : 25)



SECTION - 'A - A'



DETAILS OF R. C. C COLUMN
(SCALE - 1 : 25)





Latitude: 24.238494
Longitude: 88.262315
Elevation: 43.58±19 m
Accuracy: 28.5 m
Time: 29-10-2024 12:28
Note: Shibtalaghat W6

19


Chairman
Jaganj-Azinganj Municipality