

## Annexure-III

## Site Inspection Report for construction of CT/PT

Date: 24.01.25

ULB Name	Guskara Municipality	
Ward No	14	
Name of the proposed site	Alutia Paschim Para, Adibashi Para	
Address	Alutia Paschim Para, Ward No-14	
Category CT/PT	CT	
Necessary Land Details	Whether the Land is belongs to the ULB/Other (If Other please specify)	Plot - 2888, Khatian - 813/2, Mouja Alutia JL No - 102
	Dag No., Khatian No., J.L. No. & other plot information.	Private Land
	No objection Certificate received from the concerned authority (Yes/No)	Yes
Nearest location of CT/PT (approx distance in meter)	110	
Proposed no of Toilet seats	Male	2
	Female	3
Proposed no of Urinal seats	Male	2
	Female	3
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal <input checked="" type="checkbox"/>	
Area required for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	Model - A
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	
	Urinal (Minimum=500x600)	
Space identified for installation of Soakpit and Soak Well	Yes	
Availability of surface water/piped water supply (in details)	Available	
Operation and Maintenance plan in detail	Community user group	
Remarks if any:		
Representative assigned from Hiji Inspiration for the site inspection	Name & Designation	
	Contact No	9339875575
	Signature with Seal	
Representative assigned from the ULB for the site inspection	Name & Designation	
	Contact No	
	Signature with Seal	

24.1.25  
NODAL ENGINEER, SWM  
Guskara Municipality

Checked & Verified  
Pradeep Mukherjee  
Engineer (Civil)  
Hiji INSPIRATION