



OFFICE OF THE COUNCILLORS
Jiaganj-Azimganj Municipality

P.O.-Azimganj; Dist.-Murshidabad

West Bengal; PIN-742122.

e-mail – jamunicipality@gmail.com

Phone: 03483-253222

To whom it may concern

This is to state that the undersigned has no objection if Community Toilet (C.T) is constructed at the under describe land of the Municipality.

Location-Guripara ,Azimganj, Murshidabad, ward no-13, Under Jiaganj-Azimganj Municipality,

Owner- Jiaganj-Azimganj Municipality.

Land Details-

Mouja: -Azimganj, J.L.No.-239,

Khatian No.-369,

Plot No.-43,

Land Area-80.0 Sqm.


Chairman,
Jiaganj – Azimganj Municipality
Chairman
Jiaganj-Azimganj Municipality

Annexure-III
Site Inspection Report for construction of CT/PT

Date :


Name	JIAGANJ-AZIMGANJ	
Card No	13	
Name of the proposed site	COMMUNITY TOILET (C.T) at AZIMGANJ GURIPARA HARIJANPATTY.	
Address	AZIMGANJ	
Category CT/PT	C.T	
Necessary Land Details	Wheather the Land is belongs to the ULB/Other (If Other please specify)	ULB
	Dag No., Khatian No., J.L. No. & other plot information.	Mouza with JL :AZIMGANJ-239, Plot no:-43, Kh no:- 369,
	No objection Certificate received from the concerned authority	YES
Nearest location of CT/PT (approx distance in meter)	NA	
Proposed no of Toilet seats	Male	2
	Female	3
Proposed no of Urinal seats	Male	2
	Female	3
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal	NORMAL
Area rquired for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	CT (50.6 SQ.M)
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	1200X1350
	Urinal (Minimum=500x600)	600X500
Space identified for installation of Soakpit and Soak Well	YES	
Availability of surface water/piped water supply (in details)	YES	
Operation and Maintenance plan in detail	ULB	
Remarks if any:		
Representative assigned from Hijli Inspiration for the site inspection	Name & Designation	SHAHID ANWAR ANSARI (CIVIL ENGINEER)
	Contact No	7980028462
	Signature with Seal	
Representative assigned from the ULB for the site	Name & Designation	KOUSIK PANDEY (TECHNICAL SUPERVISOR)
	Contact No	7001198093

Checked & Verified



J. Pandey
Technical Supervisor

[Signature]
Chairman
Jaganj-Azimganj Municipality



Area Statement

Builtup Area - 24.04 Sq.m.
 Roof Area - 35.31 Sq.m.

MKD.	Size	Reinforcement	Support	Span
T8181	250x330	Top Bottom Top	Support	Span
T8282	200x250	Top Bottom Top	Support	Span
M-20	200x250	Top Bottom Top	Support	Span

Door - Window Schedule

MKD.	Size
D	750x1800
W	600x450

Model Plan No. - CT-3

GENERAL NOTES

1. ALL DIMENSIONS ARE IN MM
2. OUTER WALL IS 125 MM. TH WITH 1ST CLASS BRICKS IN CEMENT MORTER(6:1) AND PARTION WALL IS 125MM. TH. IN CEMENT MORTER(4:1)
3. GRADE OF CONCRETE M-20 ORDINARY CEMENT CONCRETE (MIX:1:5:3)
4. GRADE OF STEEL:FE-510
5. 25MM. TH D.P.(MIX:2:4) WILL BE APPLIED
6. PLASTERING: OUTSIDE-15MM. TH. IN CEMENT MORTER(1:6) INSIDE-15MM. TH. IN CEMENT MORTER(1:6) CEILING-10MM. TH. CEMENT MORTER(1:4) BEARING CAPACITY OF SOIL AT DEPTH 1M BELOW G.L. = 110 KN/M². WHICH MUCH BE EXPLODED BEFORE CONSTRUCTION. REDRAWING & REDESIGN IS NECESSARY IS BEARING CAPACITY OF SOIL IS POOR THEN ASSUMED.

Signature Of Authority



New Toilet
Harizon basti
24.23943, 88.25478

14

Chairman
Jiaganj-Azimganj Municipality