


26

Annexure-III		
Site Inspection Report for construction of CT/PT		
		Date :
ULB Name	Garulia Municipality.	
Ward No	12	
Name of the proposed site	Near Bikash Babu Basu Health Centre	
Address		
Category CT/PT	PT.	
Necessary Land Details	Whether the Land is belongs to the ULB/Other (If Other please specify)	ULB
	Dag No., Khatian No., J.L. No. & other plot information.	
	No objection Certificate received from the concerned authority (Yes/No)	yes.
Nearest location of CT/PT (approx distance in meter)	PT.	
Proposed no of Toilet seats	Male	3
	Female	2
Proposed no of Urinal seats	Male	2
	Female	2
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal	Normal
Area required for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	40 m ²
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	Toilet - 1200 x 1600
	Urinal (Minimum=500x600)	Urinal - 1600 x 1200
Space identified for installation of Soakpit and Soak Well	yes.	
Availability of surface water/piped water supply (in details)	yes.	
Operation and Maintenance plan in detail	3rd party maintenance	
Remarks if any:		
Representative assigned from Hijli Inspiration for the site inspection	Name & Designation	Prakash Mukherjee (Engineer)
	Contact No	93398 93398 7088
	Signature with Seal	 Engineer (CIVIL) Hijli INSPIRATION
Representative assigned from the ULB for the site inspection	Name & Designation	Susanta (S.A.E.)
	Contact No	9804188879
	Signature with Seal	