

Annexure-III

Site Inspection Report for construction of CT/PT

ULB Name		Garulia Municipality.		Date :
Ward No		16		
Name of the proposed site		Milan Sangha Club		
Address				
Category CT/PT		P.T.		
Necessary Land Details	Wheater the Land is belongs to the ULB/Other (If Other please specify)	others.		
	Dag No., Khatian No., J.L. No. & other plot information.			
	No objection Certificate received from the concerned authority (Yes/No)	yes.		
Nearest location of CT/PT (approx distance in meter)		P.T.		
Proposed no of Toilet seats	Male	3		
	Female	2		
Proposed no of Urinal seats	Male	2		
	Female	2		
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal	Normal.		
Area rquired for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	40m <sup>2</sup>		
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	Toilet - 1200x1600		
	Urinal (Minimum=500x600)	urinal = 1600x1200		
Space identified for installation of Soakpit and Soak Well		yes.		
Availability of surface water/piped water supply (in details)		yes.		
Operation and Maintenance plan in detail		3rd party maintenance		
Remarks if any:				
Representative assigned from Hijji Inspiration for the site inspection	Name & Designation	Prabir Mukherjee (Engineer)		
	Contact No	9339875575 Checked & Verified		
	Signature with Seal			
Representative assigned from the ULB for the site inspection	Name & Designation	Susanta Sarkar (S.A.E.)		
	Contact No	9804188879		
	Signature with Seal			

Sub-Assistant Engineer  
Garulia Municipality