

Site Inspection Report for construction of CT/PT

Date : 09.12.2024

ULB Name		Nalhati
Ward No		5
Name of the proposed site		OLD JATRI SHED OF MURARAI BUS STAND WARD NO 05
Address		NALHATI
Category CT/PT		PT
Necessary Land Details	Wheather the Land is belongs to the ULB/Other (If Other please specify)	ULB
	Dag No., Khatian No., J.L. No. & other plot information. No objection Certificate received from the concerned authority (Yes/No)	PLOT NO- 1945 JL NO- 53 MOUZA NALHATI ULB
Nearest location of CT/PT		300
Proposed no of Toilet seats	Male	1
	Female	1
Proposed no of Urinal seats	Male	2
	Female	1
To be constructed as Aspirational Toilet or Normal Toilet (only applicable for PTs)	Aspirational/Normal	Normal
Area rquired for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	22.5 SQ.M (MODEL F)
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200 , Minimum=750x900)	1200/1000m
	Urinal (Minimum=500x600)	600/500
Space identified for installation of Soakpit		Yes
Availability of surface water/piped water		No
Operation and Maintenance plan in detail		3rd Party Agency
Remarks if any:		
Representative assigned from Hijli Inspiration for the site inspection	Name & Designation	ABHIK MAJUMDAR (CIVIL. ENGINEER) Checked & Verified
	Contact No	9851301709
	Signature with Seal	<i>Abhik Majumdar</i> Engineer (Civil) Hijli Insp.
Representative assigned from the ULB for the site inspection	Name & Designation	PAPIYA DUTTA (CIVIL. ENG)
	Contact No	8617077367
	Signature with Seal	<i>Papiya Dutta</i>