



Annexure-III

Site Inspection Report for construction of CT/PT

Date: 7.07.25

	Khirpai Municipality	
	5	
Proposed	Khirpai Rural Hospital	
	Khirpai ward - 10	
Category	PS	
Necessary Land Details	Whether the Land is belongs to the ULB/Other (If Other please specify)	Hospital
	Dag No., Khatian No., J.L. No. & other plot information.	Plot - 215, Khatian - 572 Part - 1407
	No objection Certificate received from the concerned authority (Yes/No)	Yes
Nearest location of CT/PT (approx distance in meter)	10	
Proposed no of Toilet seats	Male	7
	Female	3
Proposed no of Urinal seats	Male	7
	Female	6
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal Normal	
Area required for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	Model - C
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	
	Urinal (Minimum=500x600)	
Space identified for installation of Soakpit and Soak Well	Yes	
Availability of surface water/piped water supply (in details)	Available	
Operation and Maintenance plan in detail	3rd party	
Remarks if any:		
Representative assigned from Hijli Inspiration for the site inspection	Name & Designation	
	Contact No	9339875525
	Signature with Seal	
Representative assigned from the ULB for the site inspection	Name & Designation	Manojit Das, (S.A.B)
	Contact No	9932602489
	Signature with Seal	

Sub-Assistant Engineer
Khirpai Municipality
Khirpai, Paschim Medinipur