

52-9

9

Annexure-III

Site Inspection Report for construction of CT/PT

Date :

ULB Name	Garulia	
Ward No	3	
Name of the proposed site	Govt. Quarter play ground.	
Address	Ward-3, Garulia.	
Category CT/PT	PT.	
Necessary Land Details	Whether the Land is belongs to the ULB/Other (If Other please specify)	ULB.
	Dag No., Khatian No., J.L. No. & other plot information.	SL-19.
	No objection Certificate received from the concerned authority	Yes.
Nearest location of CT/PT (approx distance in meter)	No	
Proposed no of Toilet seats	Male	1
	Female	1
Proposed no of Urinal seats	Male	2
	Female	1
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal	Normal (F)
Area required for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	22.5 sqm
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	1000 x 1200
	Urinal (Minimum=500x600)	300 x 600
Space identified for installation of Soakpit and Soak Well	Yes.	
Availability of surface water/piped water supply (in details)	Yes.	
Operation and Maintenance plan in detail	ULB / Agency.	
Remarks if any:		
Representative assigned from Hijli Inspiration for the site inspection	Name & Designation	Prabin Mukherjee (Engineer)
	Contact No	9804188 9339893375
	Signature with Seal	
Representative assigned from the ULB for the site inspection	Name & Designation	Susanta Sarkar (S.A.E.)
	Contact No	98041 58879
	Signature with Seal	

Checked & verified  
 [Signature]  
 Engineer  
 12/05/2024

See-Asstt Engineer  
 Garulia Municipality