

## Annexure-III

## Site Inspection Report for construction of CT/PT

Date :

ULB Name	Garulia.	
Ward No	6. NOAPARA SPORTING CLUB	
Name of the proposed site	"1	
Address	Ward-6, Garulia.	
Category CT/PT	PT.	
Necessary Land Details	Whether the Land is belongs to the ULB/Other (If Other please specify)	Club.
	Dag No., Khatian No., J.L. No. & other plot information.	Dag - 571, Khatian - 127.
	No objection Certificate received from the concerned authority	Yes.
Nearest location of CT/PT (approx distance in meter)	NA.	
Proposed no of Toilet seats	Male	1
	Female	1
Proposed no of Urinal seats	Male	2
	Female	1
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal Normal (F).	
Area required for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	22.5 sqm.
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	1000 x 1200
	Urinal (Minimum=500x600)	500 x 600
Space identified for installation of Soakpit and Soak Well	Yes.	
Availability of surface water/piped water supply (in details)	Yes.	
Operation and Maintenance plan in detail	Club.	
Remarks if any:		
Representative assigned from High Inspiration for the site inspection	Name & Designation	Prabir Mukherjee (Engineer)
	Contact No	9339875575
	Signature with Seal	
Representative assigned from the ULB for the site inspection	Name & Designation	Susanta Sarkar (S.A.E.)
	Contact No	9804188879
	Signature with Seal	

Checked &amp; Verified:

*[Signature]*  
Engineer (CIVIL)  
INSPIRATION

*[Signature]*  
Sub-Assistant Engineer  
Garulia Municipality