

Date :

ULB Name	Garulia	
Ward No	1F.	
Name of the proposed site	Nabin babu F.P. School.	
Address		
Category CT/PT	School PT.	
Necessary Land Details	Whether the Land is belongs to the ULB/Other (If Other please specify)	School.
	Dag No., Khatian No., J.L. No. & other plot information.	BUL- 02 19.
	No objection Certificate received from the concerned authority	yes.
Nearest location of CT/PT (approx distance in meter)	NA.	
Proposed no of Toilet seats	Male	1
	Female	1
Proposed no of Urinal seats	Male	2
	Female	1
To be constructed as Aspirational Toilet or Normal Toilet (only)	Aspirational/Normal	Normal (F).
Area required for Public Toilets	4 to 5 sq. meters per 10 toilet seats: Min. 1.5 m x 1.2 m	22.5 sqm
Area requirement details in sq mm for Community Toilets	Toilet Cubical (Optimum=900x1200, Minimum=750x900)	1000 X 1200
	Urinal (Minimum=500x600)	500 X 600
Space identified for installation of Soakpit and Soak Well	yes.	
Availability of surface water/piped water supply (in details)	yes.	
Operation and Maintenance plan in detail	School.	
Remarks if any:		
Representative assigned from Hijli for the site inspection	Name & Designation	Prabire Mukherjee (Engineer)
	Contact No	9339875575
	Signature with Seal	
Representative assigned from the ULB for the site inspection	Name & Designation	Susanta Sarkar (S.A.E.)
	Contact No	9804188379
	Signature with Seal	